

CHUCK CLARKE
Director



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

3601 W. Washington • Yakima, Washington 98903-1164 • (509) 575-2800

July 13, 1992

Charles A. Faucher
11 Riggin Road
Wapato WA 98951

Re: Emergency Drought Authorization - Charles A. Faucher
(see Ground Water Application No. G4-31160)

In accordance with the provisions of RCW 43.83B.405, it was ordered and determined by the Director of the Department of Ecology on June 29, 1992, that the Yakima River basin is under drought conditions. The Yakima River basin is comprised of Water Resource Inventory Areas 37, 38, and 39, naturally drained by the Yakima River and its tributaries.

Charles A. Faucher owns a portion of the N $\frac{1}{2}$ NE $\frac{1}{4}$ of Section 5, T. 11 N., R. 20 E.W.M., of which 23.3 acres are served irrigation water by the Roza Irrigation District.

In accordance with the guidance of Chapter 173-166 Washington Administrative Code (WAC) and the Drought Declaration Order, the Washington State Department of Ecology is issuing an Emergency Drought Authorization with the following limitations and conditions:

This EMERGENCY AUTHORIZATION will terminate on or before December 1, 1992, (the effective duration of the Order of Drought Declaration), unless sooner revoked by the Director of the Department of Ecology. This authorization shall in no manner imply or be construed to guarantee that a final (regular) permit will issue for the future use of the facility herein authorized. Ground Water Application No. G4-31160 was submitted to the Department of Ecology on February 11, 1992. A formal permit decision will be made at a future undetermined date.

Withdrawal/diversion of water under this authorization may be limited or otherwise regulated in favor of senior rights.

Yakima River water delivered by the Roza Irrigation District is normally available to serve 23.3 acres within the parcel described below.

There is less than 75% of normal water supply available for delivery to the Faucher property described above due to drought conditions in the Yakima River drainage basin. Mr. Faucher has requested in writing, authorization to construct an emergency well to supplement irrigation water normally delivered by the Roza Irrigation District.

FILE COPY

EMERGENCY AUTHORIZATION

Page 2

The emergency source authorized is a well to be located approximately 1600 feet west and 1100 feet south from the northeast corner of Section 5, T. 11 N., R. 20 E.W.M., being within the NW $\frac{1}{4}$ NE $\frac{1}{4}$ of Section 5.

The following construction requirements must be satisfied before water use as described below can be started.

Installation and maintenance of an access port as described in Ground Water Bulletin No. 1 is required. An air line and gage may be installed in addition to the access port.

All water wells constructed within the state shall meet the minimum standards for construction and maintenance as provided under RCW 18.104 (Washington Water Well Construction Act of 1971) and Chapter 173-160 WAC (Minimum Standards for Construction and Maintenance of Water Wells).

The well is authorized to be constructed into the sedimentary deposits known as the Ellensburg Formation and shall be cased and effectively sealed a minimum of 250 feet below land surface.


Monthly power meter readings shall be submitted to the Central Regional Office of the Washington State Department of Ecology during the entire period when water is being withdrawn under this right.

This EMERGENCY AUTHORIZATION is specifically to make up for deficits in the primary water supply described above. The quantity of water is limited to 240 gpm/1.5 ac-ft/ac or 35 total acre-feet for irrigation of 23.3 acres located within the following described place of use:

Lots 2 and 3 of Short Plat 80-226, being within the N $\frac{1}{2}$ NE $\frac{1}{4}$ of Section 5, T. 11 N., R. 20 E.W.M., Yakima County.

You have the right to obtain review of this order. Request for review must be made, within thirty (30) days of receipt of this order, to the Washington Pollution Control Hearings Board, PO Box 40903, Olympia, Washington 98504-0903. Concurrently, a copy of the request must be sent to the Department of Ecology, PO Box 47600, Olympia, Washington 98504-7600. These procedures are consistent with the provisions of Chapter 43.21B RCW and the rules and regulations adopted thereunder.

Sincerely,



Darlene M. Frye
Technical Unit Supervisor
Water Resources Program

DMF:HRP:ska
920722.wr2

Enclosure(s): Ground Water Bulletin No. 1