

STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY

**PERMIT**  
TO APPROPRIATE PUBLIC WATERS OF THE STATE OF WASHINGTON

<b>PRIORITY DATE</b> 2/19/2010	<b>PERMIT NUMBER</b> S3-30613
-----------------------------------	----------------------------------

<b>MAILING ADDRESS</b> WA Department of Fish & Wildlife Mr. John Whalen 2315 N. Discovery Place Spokane Valley, Washington 99216	<b>SITE ADDRESS (IF DIFFERENT)</b> Skookum Creek Fish Hatchery 469 Hatchery Road Usk, Washington 99180
--	---

**Quantity Authorized for Diversion**

DIVERSION RATE	UNITS	ANNUAL QUANTITY (AF/YR)
3	CFS	0

**Purpose**

PURPOSE	DIVERSION RATE			ANNUAL QUANTITY (AF/YR)		PERIOD OF USE
	ADDITIVE	NON-ADDITIVE	UNITS	ADDITIVE	NON-ADDITIVE	
fish propagation	3		CFS	0		01/01 - 12/31

3 cubic feet per second, continuously, for non-consumptive fish propagation

**Source Location**

COUNTY	WATERBODY	TRIBUTARY TO	WATER RESOURCE INVENTORY AREA
Pend Oreille	Unnamed Spring	Skookum Creek	62 Pend Oreille

SOURCE FACILITY/DEVICE	PARCEL	TWN	RNG	SEC	QQ Q	LATITUDE	LONGITUDE
Spring Diversion	443322220001	33 N.	44 E.	22	NW¼NW¼	48.35191	-117.23461

Datum: NAD83/WGS84

1000 feet east and 350 feet south from the NW¼ of Section 22

**Place of Use**

**PARCELS (NOT LISTED FOR SERVICE AREAS)**  
443322220001

**LEGAL DESCRIPTION OF AUTHORIZED PLACE OF USE**  
NW¼NW¼ of Section 22, Township 33 N., Range 44 E.W.M.

**Proposed Works**

Gravity feed diversion works from unnamed spring to supply water for a fish hatchery

<b>Development Schedule</b>		
<b>BEGIN PROJECT</b>	<b>COMPLETE PROJECT</b>	<b>PUT WATER TO FULL USE</b>
March 1, 2013	March 1, 2018	March 1, 2019

<b>Measurement of Water Use</b>	
How often must water use be measured?	Daily
How often must water use data be reported to Ecology?	Upon Request by Ecology
What volume should be reported?	None
What rate should be reported?	Daily Peak Rate of Withdrawal (gpm or cfs)

**Provisions**

The fish hatchery is allowed one filling or charging of the system each year, subject to existing water right. Water diversion beyond the first filling requires that inflow equals outflow. Additionally, the water returned must meet water quality standards.

Surface Water Application Nos. S3-30613 and S3-30614 shall be limited to a total of 8 cubic feet per second for non-consumptive fish propagation. The sources are not interchangeable and are restricted to the quantities authorized. The Spring Branch diversion shall be limited to 3 cfs as a maximum and the Skookum Creek diversion shall be limited to 5 cfs as a maximum.

**Measurements, Monitoring, Metering and Reporting**

An approved measuring device shall be installed and maintained for each of the sources identified by this water right in accordance with the rule "Requirements for Measuring and Reporting Water Use", WAC 173-173.

WAC 173-173 describes the requirements for data accuracy, device installation and operation, and information reporting. It also allows a water user to petition the Department of Ecology for modifications to some of the requirements.

**Department of Fish and Wildlife Requirement(s)**

The intake(s) shall be screened in accordance with Department of Fish and Wildlife screening criteria (pursuant to RCW 77.57.010, RCW 77.57.070, and RCW 77.57.040). Contact the Department of Fish and Wildlife, 600 Capitol Way N, Olympia, WA 98501-1091. Attention: Habitat Program, Phone: (360) 902-2534 if you have questions about screening criteria. <http://www.wdfw.wa.gov/reg/regions.htm>

A permit from the Department of Fish and Wildlife may be needed to raise fish in any state waters: <http://www.wdfw.wa.gov/reg/regions.htm>.

**Water Use Efficiency**

Use of water under this authorization shall be contingent upon the water right holder's maintenance of efficient water delivery systems and use of up-to-date water conservation practices consistent with established regulation requirements and facility capabilities.

**Proof of Appropriation**

The water right holder shall file the notice of Proof of Appropriation of water (under which the certificate of water right is issued) when the permanent distribution system has been constructed and the quantity of water required by the project has been put to full beneficial use. The certificate will reflect the extent of the project perfected within the limitations of the permit. Elements of a proof inspection may include, as appropriate, the source(s), system instantaneous capacity, beneficial use(s), annual quantity, place of use, and satisfaction of provisions.


**Schedule and Inspections**

Department of Ecology personnel, upon presentation of proper credentials, shall have access at reasonable times, to the project location, and to inspect at reasonable times, records of water use, wells, diversions, measuring devices and associated distribution systems for compliance with water law.

This permit shall be subject to cancellation should the permittee fail to comply with the above development schedule and/or to give notice to the Department of Ecology on forms provided by that Department documenting such compliance.

Dated this 20<sup>th</sup> day of February, 2013, at Spokane, Washington,

Department of Ecology

by   
Keith L. Stoffel, Section Manager

DATA REVIEW  
OK 

KLS/KT:md  
W: Permits/Tusa/2013/WDFW S3-30613 permit 1-30-2013.doc