



State of Washington
PERMIT
TO APPROPRIATE PUBLIC WATERS OF THE
STATE OF WASHINGTON

File NR G2-30575
WR Doc ID 4735440

| | |
|--------------------------------------|---------------------------------------|
| PRIORITY DATE May 27, 2011 | WATER RIGHT NUMBER G2-30575 |
|--------------------------------------|---------------------------------------|

| | |
|---|------------------------------------|
| MAILING ADDRESS City of Gig Harbor 3510 Grandview Street Gig Harbor, Washington 98335 | SITE ADDRESS (IF DIFFERENT) |
|---|------------------------------------|

Quantity Authorized for Withdrawal or Diversion

| | | |
|--|---------------------|---|
| WITHDRAWAL OR DIVERSION RATE 1,000 | UNITS GPM | ANNUAL QUANTITY (AF/YR) 1,000 |
|--|---------------------|---|

Purpose

| PURPOSE | WITHDRAWAL OR DIVERSION RATE | | | ANNUAL QUANTITY (AF/YR) | | PERIOD OF USE (mm/dd) |
|------------------|------------------------------|--------------|-------|-------------------------|--------------|--------------------------|
| | ADDITIVE | NON-ADDITIVE | UNITS | ADDITIVE | NON-ADDITIVE | |
| Municipal Supply | | 1,000 | GPM | 1,000 | | 01/01 - 12/31 |

| ADDITIVE | IRRIGATED ACRES | | PUBLIC WATER SYSTEM INFORMATION | |
|----------|-----------------|--|---------------------------------|-------------|
| | NON-ADDITIVE | | WATER SYSTEM ID | CONNECTIONS |
| | | | 276009 | |

Source Location

| | | | |
|-------------------------|----------------------------------|----------------------------|---|
| COUNTY Pierce | WATERBODY Deep Aquifer | TRIBUTARY TO N/A | WATER RESOURCE INVENTORY AREA 15 - Kitsap |
|-------------------------|----------------------------------|----------------------------|---|

| | | | | | | | | |
|--|-----------------------------|-----------------|-------------------|-------------------|-----------------|---------------------|----------------------|-----------------------|
| SOURCE FACILITY/DEVICE Well No. 11 | PARCEL 9902095003 | WELL TAG | TWN 21N | RNG 02E | SEC 6 | QQ Q NWSW | LATITUDE - | LONGITUDE - |
|--|-----------------------------|-----------------|-------------------|-------------------|-----------------|---------------------|----------------------|-----------------------|

Place of Use (See Attached Map)

PARCELS (NOT LISTED FOR SERVICE AREAS)
N/A

LEGAL DESCRIPTION OF AUTHORIZED PLACE OF USE
The place of use (POU) of this water right is the service area described in the most recent Water System Plan approved by the Washington State Department of Health, so long as the water system is and remains in compliance with the criteria in RCW 90.03.386(2). RCW 90.03.386 may have the effect of revising the place of use of this water right.

PERMIT



Proposed Works

Preliminary design of Well No. 11 includes a completed depth of approximately 935 feet below ground surface (bgs) with a 10-inch diameter casing and a well screen assembly from 640 to 925 feet bgs. Four water bearing intervals within the Deep Aquifer will be screened with 40-slot well screen for a total open interval of approximately 205 feet.

Preliminary well design is based on the geologic conditions encountered in Well No. 11T (test well), located approximately 100 feet east of the proposed well location.

Development Schedule

| BEGIN PROJECT | COMPLETE PROJECT | PUT WATER TO FULL USE |
|---------------|------------------|-----------------------|
| Begun | June 1, 2015 | June 1, 2028 |

Measurement of Water Use

| | |
|---|--------------------------------------|
| How often must water use be measured? | Weekly |
| How often must water use data be reported to Ecology? | Annually |
| What volume should be reported? | Total Annual Volume |
| What rate should be reported? | Annual Peak Rate of Withdrawal (gpm) |

Provisions

Measurements, Monitoring, Metering and Reporting

An approved measuring device shall be installed and maintained for the source identified by this water right in accordance with the rule "Requirements for Measuring and Reporting Water Use", WAC 173-173, which describes the requirements for data accuracy, device installation and operation, and information reporting. It also allows a water user to petition the Department of Ecology for modifications to some of the requirements.

Ecology is requiring the recording and reporting of meter data as described above to collect seasonal information for water resource planning and compliance.

Water use shall be recorded weekly. Recorded water use data may be submitted via the Internet. To set up an Internet reporting account, contact the Southwest Regional Office. If you do not have Internet access, you can still submit hard copies by contacting the Southwest Regional Office for forms to submit your water use data.

Department of Ecology personnel, upon presentation of proper credentials, shall have access at reasonable times to the project location, and will be allowed to inspect, at reasonable times, records of water use, wells, diversions, measuring devices and associated distribution systems to ensure there is compliance with the law.

Proof of Appropriation

The water right holder shall file the notice of Proof of Appropriation of water when the quantity of water required by the project has been put to full beneficial use. The certificate will reflect the extent of the project perfected within the limitations of the permit. Elements of a proof inspection may include, as appropriate, the source(s), system instantaneous capacity, beneficial use(s), annual quantity, place of use, and satisfaction of provisions.

This permit shall be subject to cancellation should the permittee fail to comply with the above development schedule and/or to give notice to the Department of Ecology on forms provided by that department documenting such compliance.

Given under my hand and the seal of this office at Olympia, Washington,

this 20th day of June, 2012.

Department of Ecology

OK RC

By Michael J. Gallagher
Michael J. Gallagher, Section Manager

