



State of Washington
PERMIT
TO APPROPRIATE PUBLIC WATERS OF THE
STATE OF WASHINGTON

PRIORITY DATE
January 20, 2011

WATER RIGHT NUMBER
G2-30565

MAILING ADDRESS
City of Washougal
1701 C Street
Washougal, WA 98671

SITE ADDRESS (IF DIFFERENT)

Quantity Authorized for Withdrawal or Diversion

WITHDRAWAL OR DIVERSION RATE	UNITS	ANNUAL QUANTITY (AF/YR)
4,675	GPM	3,786

Purpose

PURPOSE	WITHDRAWAL OR DIVERSION RATE			ANNUAL QUANTITY (AF/YR)		PERIOD OF USE (mm/dd)
	ADDITIVE	NON-ADDITIVE	UNITS	ADDITIVE	NON-ADDITIVE	
Municipal Supply		4,675	GPM		3,786	01/01 - 12/31

ADDITIVE	IRRIGATED ACRES		PUBLIC WATER SYSTEM INFORMATION	
	NON-ADDITIVE		WATER SYSTEM ID	CONNECTIONS
			93400	

Source Location

COUNTY	WATERBODY	TRIBUTARY TO	WATER RESOURCE INVENTORY AREA
Clark	Groundwater	N/A	28

SOURCE FACILITY/DEVICE	PARCEL	WELL TAG	TWN	RNG	SEC	QQ Q	LATITUDE	LONGITUDE
Well No. 5	89935000		1N	3E	12	NW SE		
Well No.6	89935000		1N	3E	12	NW SE		
Well No.7	89935000		1N	3E	12	NW SE		
Well No.11	89935000		1N	3E	12	NW SE		
Well No.12	89935000	APN125	1N	3E	12	NW SE		

PERMIT

Place of Use (See Attached Map)

PARCELS (NOT LISTED FOR SERVICE AREAS)

N/A

LEGAL DESCRIPTION OF AUTHORIZED PLACE OF USE

Area served by the City of Washougal as described in the mostly recent Water System Plan approved by the Department of Health

Proposed Works

Lower Wellfield, consisting of existing Well Nos. 5, 6, 7, 11, and 12 with casings up to 16" in diameter and ranging in depth from 75 to 150 feet deep. All five wells are currently available for use.

Development Schedule

BEGIN PROJECT	COMPLETE PROJECT	PUT WATER TO FULL USE
Begun	Completed	December 31, 2030

Measurement of Water Use

How often must water use be measured?	Weekly
How often must water use data be reported to Ecology?	Annually
What volume should be reported?	Total Annual Volume
What rate should be reported?	Annual Peak Rate of Withdrawal (gpm)

Provisions

Measurements, Monitoring, Metering and Reporting

An approved measuring device must be installed and maintained for each of the sources identified by this water right in accordance with the rule "Requirements for Measuring and Reporting Water Use", WAC 173-173.

Department of Ecology personnel, upon presentation of proper credentials, must have access at reasonable times, to the records of water use that are kept to meet the above conditions, and to inspect at reasonable times any measuring device used to meet the above conditions.

WAC 173-173 describes the requirements for data accuracy, device installation and operation, and information reporting. It also allows a water user to petition the Department of Ecology for modifications to some of the requirements.

Proof of Appropriation

The water right holder must file the notice of Proof of Appropriation of water (under which the certificate of water right is issued) when the permanent distribution system has been constructed and the quantity of water required by the project has been put to full beneficial use. The certificate will reflect the extent

This permit shall be subject to cancellation should the permittee fail to comply with the above development schedule and/or to give notice to the Department of Ecology on forms provided by that department documenting such compliance.

Given under my hand and the seal of this office at Olympia, Washington,

this 20th day of June, 2012.

Department of Ecology

OK FE

By Michael J. Gallagher
Michael J. Gallagher, Section Manager