



DEPARTMENT OF  
**ECOLOGY**  
State of Washington

File NR G2-29174  
WR Doc ID 2221314

State of Washington  
**WATER RIGHT PERMIT**

**PRIORITY DATE**

1/3/1995

**WATER RIGHT NUMBER**

G2-29174

**MAILING ADDRESS**

RIDGEFIELD CITY  
230 PIONEER AVENUE  
RIDGEFIELD WA 98642

**SITE ADDRESS (IF DIFFERENT)**

**Quantity Authorized for Withdrawal or Diversion**

**WITHDRAWAL OR DIVERSION RATE**  
400

**UNITS**  
Unit

**ANNUAL QUANTITY (AF/YR)**  
483

**Purpose**

PURPOSE	WITHDRAWAL OR DIVERSION RATE			ANNUAL QUANTITY (AF/YR)		PERIOD OF USE (mm/dd)
	ADDITIVE	NON-ADDITIVE	UNITS	ADDITIVE	NON-ADDITIVE	
Municipal supply	400		GPM	483		01/01 - 12/31

ADDITIVE	IRRIGATED ACRES		PUBLIC WATER SYSTEM INFORMATION	
	NON-ADDITIVE		WATER SYSTEM ID	CONNECTIONS
			72400V	

**Source Location**

COUNTY	WATERBODY	TRIBUTARY TO	WATER RESOURCE INVENTORY AREA
CLARK	GROUNDWATER		27-LEWIS

SOURCE FACILITY/DEVICE	PARCEL	WELL TAG	TWP	RNG	SEC	QQ Q	LATITUDE	LONGITUDE
WELL			04N	01E	21			

Datum: NAD83/WGS84

**Place of Use (See Attached Map)**

**PARCELS (NOT LISTED FOR SERVICE AREAS)**

N/A

**LEGAL DESCRIPTION OF AUTHORIZED PLACE OF USE**

The place of use (POU) of this water right is the service area described in the most recent Water System Plan approved by the Washington State Department of Health, so long as the water system is and remains in compliance with the criteria in RCW 90.03.386(2). RCW 90.03.386 may have the effect of revising the place of use of this water right.

WATER RIGHT PERMIT

### Proposed Works

The well be equipped with a 400-gallon per minute (gpm) pump and will supply the Junction Reservoir, an existing 100,000 gallon above ground storage tank. The Junction Booster Station consists of three 1,000 gpm end suction centrifugal pumps and one 10 gpm vertical multi-stage pump. The Junction Booster Station provides water to the water system High Zone from the Junction Reservoir.

### Development Schedule

BEGIN PROJECT	COMPLETE PROJECT	PUT WATER TO FULL USE
Started	January 1, 2015	March 1, 2020

### Measurement of Water Use

How often must water use be measured?	Monthly
How often must water use data be reported to Ecology?	Upon Request by Ecology
What volume should be reported?	None
What rate should be reported?	Annual Peak Rate of Withdrawal (gpm or cfs)

### Provisions

#### Measurements, Monitoring, Metering and Reporting

An approved measuring device must be installed and maintained for each of the sources identified by this water right in accordance with the rule "Requirements for Measuring and Reporting Water Use", WAC 173-173 , which describes the requirements for data accuracy, device installation and operation, and information reporting. It also allows a water user to petition the Department of Ecology for modifications to some of the requirements.

Department of Ecology personnel, upon presentation of proper credentials, shall have access at reasonable times, to the project location, and to inspect at reasonable times, records of water use, wells, diversions, measuring devices and associated distribution systems for compliance with water law.

#### Proof of Appropriation

The water right holder shall file the notice of Proof of Appropriation of water (under which the certificate of water right is issued) when the permanent distribution system has been constructed and the quantity of water required by the project has been put to full beneficial use. The certificate will reflect the extent of the project perfected within the limitations of the permit. Elements of a proof inspection may include, as appropriate, the source(s), system instantaneous capacity, beneficial use(s), annual quantity, place of use, and satisfaction of provisions.

#### This Permit Subject to Cancellation

This permit shall be subject to cancellation should the permittee fail to comply with the above development schedule and/or to give notice to the Department of Ecology on forms provided by the Department documenting such compliance.

Given under my hand and the seal of this office at Olympia, Washington this 18<sup>th</sup> day of October 2012.

Department of Ecology

OK PC

by Michael J. Gallagher  
Michael J. Gallagher  
Section Manager