


APPLICATION FOR PERMIT

RECEIVED

JUL 01 1992

I have examined the application for a permit to appropriate public waters of the State of Washington as required by RCW 90.03 and find that it is:  SURFACE WATER  GROUND WATER



WASHINGTON STATE DEPARTMENT OF ECOLOGY

DATE 7/24/92

SIGNATURE Shaka Baker

\$10.00 MINIMUM STATUTORY EXAMINATION FEE REQUIRED WITH APPLICATION LOCATION ECOLOGY (GRAY BOXES FOR OFFICE USE ONLY)

APPLICATION NO. 51-216658	W.R.I.A. 3	COUNTY Skagit	PRIORITY DATE 7.1.92	TIME	ACCEPTED SP
---------------------------	------------	---------------	----------------------	------	-------------

REJECTED

APPLICANT'S NAME - PLEASE PRINT Alyn F. Rensink

Bus. Tel. \_\_\_\_\_  
Home Tel. 691-6268  
Other Tel. \_\_\_\_\_

ADDRESS (STREET) 21400 118th PL NE (CITY) Granite Falls (STATE) WA (ZIP CODE) 98252

1. SOURCE OF SUPPLY

IF SURFACE WATER	IF GROUND WATER
SOURCE (NAME OF STREAM, LAKE, SPRING, ETC.) (IF UNNAMED, SO STATE) Unnamed Stream	SOURCE (WELL, TUNNEL, INFILTRATION TRENCH, ETC.)
TRIBUTARY	SIZE AND DEPTH

2. USE

USE TO WHICH WATER IS TO BE APPLIED (DOMESTIC SUPPLY, IRRIGATION, MINING, MANUFACTURING, ETC.) Hydroelectric - continuously

ENTER QUANTITY OF WATER REQUESTED USING UNITS OF: CUBIC FEET PER SECOND (CFS) 5 OR GALLONS PER MINUTE (GPM) ACRE FEET PER YEAR

TIMES DURING YEAR WATER WILL BE REQUIRED YEAR AROUND

IF IRRIGATION, NUMBER OF ACRES	IF DOMESTIC USE, NUMBER OF UNITS BY TYPE, E.G. 1-HOME, 1-MOBILE HOME, 2-CAMPSITES, ETC.	IF MUNICIPAL USE, ESTIMATED POPULATION 20 YEARS FROM TODAY
DATE PROJECT WAS OR WILL BE STARTED ASAP	DATE PROJECT WAS OR WILL BE COMPLETED UNKNOWN (when home is completed)	

3. LOCATION OF POINT OF DIVERSION/WITHDRAWAL

3A. IF IN PLATTED PROPERTY

LOT	BLOCK	OF (GIVE NAME OF PLAT OR ADDITION)	SECTION	TOWN	RANGE	ALSO, PLEASE ENCLOSE A COPY OF THE PLAT AND MARK THE POINT(S) OF WITHDRAWAL OR DIVERSION

3B. IF NOT IN PLATTED PROPERTY

ON ACCOMPANYING SECTION MAPS, ACCURATELY MARK AND IDENTIFY EACH POINT OF DIVERSION. SHOW NORTH-SOUTH AND EAST-WEST DISTANCES FROM NEAREST SECTION CORNER OR PROPERTY CORNER

ALSO, ENTER BELOW THE DISTANCES FROM THE NEAREST SECTION OR PROPERTY CORNER TO THE DIVERSION OR WITHDRAWAL.

LOCATED WITHIN (SMALLEST LEGAL SUBDIVISION) Tract 3 of lot 1 Government lot 1	SECTION 24	TOWNSHIP N. 35	RANGE (E. OR W.) W.M. 6 E	COUNTY Skagit
---	------------	----------------	---------------------------	---------------

4. DO YOU OWN THE LAND ON WHICH THIS SOURCE IS LOCATED. IF NOT, INSERT NAME & ADDRESS OF OWNER

5. LEGAL DESCRIPTION OF PROPERTY ON WHICH WATER IS TO BE USED

ATTACH A COPY OF THE LEGAL DESCRIPTION OF THE PROPERTY (ON WHICH THE WATER WILL BE USED) TAKEN FROM A REAL ESTATE CONTRACT, PROPERTY DEED OR TITLE INSURANCE POLICY. OR, COPY CAREFULLY IN THE SPACE BELOW.

Tract 3 of that certain survey recorded May 7, 1990 in Vol. 9, pg. 125, File # 9005070053, being a portion of govt. lot 1, sec. 24, Tnshp. 35 N, R 6 E, W.M. records of Skagit County, WA.

WHAT IS YOUR INTEREST IN THE PROPERTY ON WHICH THE WATER IS TO BE USED (PROPERTY OWNER, LESSEE, CONTRACT PURCHASER, ETC.)

OWNER (contract purchaser)

ARE THERE ANY EXISTING WATER RIGHTS RELATED TO THE LAND ON WHICH THE WATER IS TO BE USED (INCLUDING WATER PROVIDED BY IRRIGATION DISTRICTS OR DITCH COMPANIES.)

YES  NO

IF YES, FROM WHAT SOURCE (i.e. SURFACE OR GROUND WATER) AND UNDER WHAT AUTHORITY

6. DESCRIPTION OF SYSTEM PROPOSED OR INSTALLED

(FOR EXAMPLE: SIZE OF PUMP, CAPACITY OF PUMP, PUMP MOTOR HORSE POWER, PIPE DIAMETER, NUMBER OF SPRINKLERS, ETC.)

**REJECTED**  
8" Dia. pipe drawing water from creek (no diversion structure installed) at the max. rate of 3 ft. per sec. Water returns to stream at lower elevation (200+ ft.) after passing through powerhouse containing a 12 kW (approx.) impulse turbine/generator.

REMARKS  
7. This is a spring fed stream, with constant flow. No fish in stream as it falls vertically over rock cliffs, before entering another stream that flows into Skagit.

8. COMPLETE THIS SECTION ONLY IF THIS APPLICATION INCLUDES IRRIGATION AS A USE

IN ORDER TO IMPLEMENT THE PROVISIONS OF INITIATIVE MEASURE NUMBER 59, THE FAMILY FARM WATER ACT WHICH WAS PASSED BY THE VOTERS ON NOVEMBER 3, 1977, WE MUST ASK THE FOLLOWING QUESTIONS:

DOES THE TOTAL NUMBER OF ACRES IN WHICH YOU HAVE CONTROLLING INTEREST IN THE STATE OF WASHINGTON EXCEED 2000 ACRES FOR THE FOLLOWING THREE CATEGORIES:

- 1. LANDS THAT ARE BEING IRRIGATED UNDER WATER RIGHTS ACQUIRED AFTER DECEMBER 8, 1977. YES  NO
- 2. LANDS THAT MAY BE IRRIGATED UNDER APPLICATIONS NOW ON FILE WITH THE DEPARTMENT OF ECOLOGY. YES  NO
- 3. LANDS THAT MAY BE IRRIGATED UNDER THIS APPLICATION. YES  NO

IF 10 ACRE-FEET OR MORE OF WATER IS TO BE STORED AND/OR IF THE WATER DEPTH WILL BE 10 FEET OR MORE AT THE DEEPEST POINT, A STORAGE PERMIT MUST BE FILED IN ADDITION TO THIS PERMIT. THESE FORMS CAN BE SECURED, TOGETHER WITH INSTRUCTIONS, FROM THE DEPARTMENT OF ECOLOGY.

SIGNATURES

*Alyn F. Rensink*  
APPLICANT'S SIGNATURE

*Alyn F. + Mary J. Rensink*  
LEGAL LANDOWNERS NAME (PLEASE PRINT)

*Alyn F. Rensink Mary J. Rensink*  
LEGAL LANDOWNER'S SIGNATURE (OWNER OF PROPERTY DESCRIBED IN ITEM NUMBER 5)

*21400 118th PL NE Granite Falls, WA, 98252*  
LEGAL LANDOWNER'S ADDRESS

FOR OFFICE USE ONLY

STATE OF WASHINGTON }  
DEPARTMENT OF ECOLOGY } ss.


This is to certify that I have examined this application together with the accompanying maps and data, and am returning it for correction or completion as follows: .....

In order to retain its priority date, this application must be returned to the Department of Ecology, with corrections, on or before ....., 19.....

Witness my hand this ..... day of ....., 19.....

SECTION MAP

Sec. 24 Twp. 35 N. R. 6 E



Scale: 1 inch = 800 feet (each small square = 10 acres)


Show by a cross (X) the location of point of diversion (surface water source) or point of withdrawal (ground water source). For ground water applications, show by a circle (O) the locations of other wells or works within a quarter of a mile.

Indicate traveling directions from nearest town in space below.


13 miles east of Hwy. #9 on south Skagit Hwy.  
14 miles from Sedro Wooley + 10 mi. W. of Concrete.

Detach here

Fold along scale



Detach this scale at the performance, fold excess paper under or cut off excess by cutting along the scale line. This scale corresponds to the SECTION MAP above. You can read feet directly from this scale to outline property and locate points of diversion or withdrawal on the SECTION MAP. Enclose this map along with the application and \$10.00 examination fee.



Your water right application will be processed by the Regional Office of the Department of Ecology having jurisdiction in the area in which your water works are located. **Please submit your completed application form, maps, sketches, and \$10.00 examination fee to the appropriate Regional Office.**

Northwest Regional Office  
 3190 - 160th Avenue S.E.  
 Bellevue, WA 98008-5452  
 Tel. (206) 649-7000

Central Regional Office  
 3601 West Washington  
 Yakima, Washington 98903-1164  
 Tel. (509) 575-2800

Southwest Regional Office  
 7272 Cleanwater Lane  
 Olympia, Washington 98504-6811  
 Tel. (206) 586-6380

Eastern Regional Office  
 N. 4601 Monroe, Suite 100  
 Spokane, Washington 99205-1295  
 Tel. (509) 456-2926

The appropriate Regional Office will be happy to answer any further questions you may have.