STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY
PO Box 47775 • Olympia, Washington 98504-7775 • (360) 407-6300

February 16, 2012

City of Lacey
Attn Julie Rector
420 College Street SE
Lacey WA 98503

Re: Water Right Application No. G2-29165

Dear Ms. Rector:

Enclosed is a copy of the Department of Ecology's *Report of Examination.* This report contains our decision regarding your application.

Your application has been approved.

A Permit will be issued consistent with the enclosed *Report of Examination* after the appeal period has expired, if no appeals have been filed.

YOUR RIGHT TO APPEAL

You have a right to appeal this Order to the Pollution Control Hearing Board (PCHB) within 30 days of the date of receipt of this Order. The appeal process is governed by Chapter 43.21B RCW and Chapter 371-08 WAC. "Date of receipt" is defined in RCW 43.21B.001(2).

To appeal you must do the following within 30 days of the date of receipt of this Order:

File your appeal and a copy of this decision with the PCHB (see addresses below). Filing means actual receipt by the PCHB during regular business hours.

- Serve a copy of your appeal and this Order on Ecology in paper form - by mail or in person. (See addresses below.) E-mail is not accepted.
- You must also comply with other applicable requirements in Chapter 43.21B RCW and Chapter 371-08 WAC.

ADDRESS AND LOCATION INFORMATION

Street Addresses	Mailing Addresses
Department of Ecology Attn: Appeals Processing Desk 300 Desmond Drive SE Lacey, WA 98503	**Department of Ecology** Attn: Appeals Processing Desk PO Box 47608 Olympia, WA 98504-7608
Pollution Control Hearings Board 1111 Israel RD SW STE 301 Tumwater, WA 98501	**Pollution Control Hearings Board** PO Box 40903 Olympia, WA 98504-0903

For additional information visit the Environmental Hearings Office Website: http://www.eho.wa.gov . *To find laws and agency rules visit the Washington State Legislature Website:* http://www1.leg.wa.gov/CodeReviser.

If you have any questions, please call (360) 407-6300.

Sincerely,

Michael J. Gallagher

Michael J. Gallagher
Section Manager
Water Resources Program

Enclosures: Report of Examination
Your Right To Be Heard

By Certified Mail: 7009 3410 0000 1272 8972

File NR G2-29165

DEPARTMENT OF ECOLOGY
State of Washington

State of Washington
REPORT OF EXAMINATION
FOR WATER RIGHT APPLICATION

APPLICATION PRIORITY DATE	WATER RIGHT NUMBER
December 16, 1994	G2-29165

MAILING ADDRESS	SITE ADDRESS (IF DIFFERENT)
City of Lacey 420 College Street SE Lacey, Washington 98503	8826 Milbanke Drive SE Olympia, Washington 98513

Quantity Authorized for Withdrawal or Diversion

WITHDRAWAL OR DIVERSION RATE	UNITS	ANNUAL QUANTITY (AF/YR)
2,000*	GPM	2,226

*Non-additive to the existing quantities authorized to the Madrona Wellfield (see Table 2).

Purpose

PURPOSE	WITHDRAWAL OR DIVERSION RATE			ANNUAL QUANTITY (AF/YR)		PERIOD OF USE (mm/dd)
	ADDITIVE	NON-ADDITIVE	UNITS	ADDITIVE	NON-ADDITIVE	
Municipal Supply		2,000	GPM	2,226		Year round

IRRIGATED ACRES		PUBLIC WATER SYSTEM INFORMATION	
ADDITIVE	NON-ADDITIVE	WATER SYSTEM ID	CONNECTIONS
		43500	

Source Location

COUNTY	WATERBODY	TRIBUTARY TO	WATER RESOURCE INVENTORY AREA
Thurston	Qc Aquifer		11 – Nisqually

SOURCE FACILITY/DEVICE	PARCEL	WELL TAG	TWN	RNG	SEC	QQ Q	LATITUDE	LONGITUDE
Well No. 21	60330006500	ABY233	18N	01W	24	NWNW	47° 2'18.71"N	122°45'16.68"W
Well No. 22	60330006500	ACR769	18N	01W	24	NWNW	47° 2'18.87"N	122°45'17.16"W
Well No. 23	60330006600	AEC883	18N	01W	24	NWNW	47° 2'18.74"N	122°45'17.60"W

Datum: NAD83/WGS84

Place of Use

LEGAL DESCRIPTION OF AUTHORIZED PLACE OF USE

The place of use (POU) of this water right is the service area described in the most recent Water System Plan approved by the Washington State Department of Health, so long as the water system is and remains in compliance with the criteria in RCW 90.03.386(2). RCW 90.03.386 may have the effect of revising the place of use of this water right.

Proposed Works

The Madrona Wellfield consists of three wells (Nos. 21, 22, and 23). Well Nos. 21 and 22 were completed to a depth of 334 feet below ground surface (bgs) with a 16-inch diameter casing and a 14-inch well screen assembly from 259 to 329 and 262 to 334 feet bgs, respectively. Three intervals in the Qc aquifer are screened in each well with 30- to 150-slot well screen for a total open interval of approximately 32 (Well No. 21) and 42 (Well No. 22) feet. Similarly, Well No. 23 was completed to a depth of 338 feet bgs with a 20-inch diameter casing and an 18-inch well screen assembly from 259.5 to 262.5 feet bgs. Two intervals in the Qc aquifer are for a total open interval of approximately 54 feet.

Development Schedule

BEGIN PROJECT	COMPLETE PROJECT	PUT WATER TO FULL USE
Begun	Complete	June 1, 2031

Measurement of Water Use

How often must water use be measured?	Weekly
How often must water use data be reported to Ecology?	Annually (by January 31)
What volume should be reported?	Total Annual Volume & Report-Volume
What rate should be reported?	Weekly Peak Rate of Withdrawal (gpm)

Provisions

Mitigation

The use of water under this permit is subject to the fulfillment of the Comprehensive Water Rights Mitigation Plan, presented in Lacey (2010) and as amended below, and continued agreement between the cities of Olympia, Lacey, and Yelm through the supporting Amended Interlocal Agreement (presented in Appendix D of City of Lacey (2010)).

A single joint Mitigation Summary Report shall be prepared by the three cities and submitted to Ecology annually. At a minimum, the report shall include:

- Development and performance of the previous year's basin-specific (Woodland Creek, McAllister Creek, Nisqually River, and Deschutes River) out-of-kind mitigation actions;
- Development and performance of the previous year's basin-specific in-kind mitigation actions. The summary of performance shall be supported by available data (e.g. estimates of monthly infiltration rates at the Woodland Creek infiltration facility);
- Completed city-specific mitigation actions by basin;
- Applicable water right permit development, by phase (1, 2, and 3);
- Comparison between permit development and corresponding completed mitigation actions; and
- Identification of mitigation actions not completed, if any, including a revised schedule and proposed limitations on permit development until completed.

For brevity, the summary report may include appendices of construction and/or monitoring reports. The annual Mitigation Summary Report for the previous year is due to Ecology on January 31. The first summary report is due on January 31, 2013. The third unnamed water right referenced under the Mitigation Plan in the Deschutes Basin is not a required mitigation element under this water right approval.

Measurements, Monitoring, Metering and Reporting
An approved measuring device shall be installed and maintained for the source identified by this water right in accordance with the rule "Requirements for Measuring and Reporting Water Use", WAC 173-173, which describes the requirements for data accuracy, device installation and operation, and information reporting. It also allows a water user to petition the Department of Ecology for modifications to some of the requirements.

Water use shall be recorded weekly. Recorded water use data may be submitted via the Internet. To set up an Internet reporting account, contact the Southwest Regional Office. If you do not have Internet access, you can still submit hard copies by contacting the Southwest Regional Office for forms to submit your water use data.

Department of Ecology personnel, upon presentation of proper credentials, shall have access at reasonable times to the project location, and will be allowed to inspect, at reasonable times, records of water use, wells, diversions, measuring devices and associated distribution systems to ensure there is compliance with the law.

Water Level Measurements
Static water levels shall be measured and recorded monthly, using a consistent methodology. Data for the previous year shall be submitted by January 31 to the Department of Ecology.

Proof of Appropriation
The water right holder shall file the notice of Proof of Appropriation of water when the permanent distribution system has been constructed and the quantity of water required by the project has been put to full beneficial use. The certificate will reflect the extent of the project perfected within the limitations of the permit. Elements of a proof inspection may include, as appropriate, the source(s), system instantaneous capacity, beneficial use(s), annual quantity, place of use, and satisfaction of provisions.

Findings of Facts
Upon reviewing the investigator's report, I find all facts, relevant and material to the subject application, have been thoroughly investigated.

Therefore, I ORDER approval of Application No. G2-29165, subject to existing rights and the provisions specified above.

Signed at Olympia, Washington, this 16th day of February 2012.

Michael J. Gallagher

Michael J. Gallagher, Section Manager

Your Right To Appeal

You have a right to appeal this Order to the Pollution Control Hearing Board (PCHB) within 30 days of the date of receipt of this Order. The appeal process is governed by Chapter 43.21B RCW and Chapter 371-08 WAC. "Date of receipt" is defined in RCW 43.21B.001(2).

To appeal you must do the following within 30 days of the date of receipt of the Order.

File your appeal and a copy of this Order with the PCHB (see addresses below). Filing means actual receipt by the PCHB during regular business hours.

- Serve a copy of your appeal and this Order on Ecology in paper form - by mail or in person. (See addresses below.) E-mail is not accepted.

  You must also comply with other applicable requirements in Chapter 43.21B RCW and Chapter 371-08 WAC.

Mailing Addresses	Street Addresses
Pollution Control Hearings Board PO Box 40903 Olympia, WA 98504-0903	**Pollution Control Hearings Board** 1111 Israel RD SW Ste 301 Tumwater, WA 98501
Department of Ecology Attn: Appeals Processing Desk PO Box 47608 Olympia, WA 98504-7608	**Department of Ecology** Attn: Appeals Processing Desk 300 Desmond Drive SE Lacey, WA 98503

For additional information visit the Environmental Hearings Office Website: http://www.eho.wa.gov. To find laws and agency rules visit the Washington State Legislature Website: http://www1.leg.wa.gov/CodeReviser.

BACKGROUND

On December 16, 1994, the City of Lacey (Lacey) filed an Application for a Water Right (G2-29165) with the Washington State Department of Ecology (Ecology) for a permit to appropriate public groundwater. The applicant requested authorization for an instantaneous withdrawal rate (Qi) of 2,000 (non-additive) gallons per minute (gpm) and a total annual withdrawal volume (Qa) of 2,226 (additive) acre-feet per year (afy) from three existing wells known as the Madrona Wellfield.

The Madrona Wellfield is currently permitted for 4,798 gpm and 3,196.80 afy, including an additional 1877.5 afy (non-additive). Construction and testing of the three production wells is documented in PGG (1996, 1997, and 2002).

Planned use of the appropriation is for general municipal supply. Lacey's water system currently serves approximately 65,000 residents, and is anticipated to serve 135,000 residents plus commercial at full buildout of the Urban Growth Area (UGA). Lacey's water system consists of water withdrawal, conveyance, and treatment facilities. The place of use is consistent with the City of Lacey 2003 Water Comprehensive Plan (Gray and Osborne) which is within the designated city water service area.

Table 1 – Application Summary

Attributes	Summary
Name	City of Lacey – Madrona Wellfield
Date	December 16, 1994
Instantaneous Quantity	2,000 gpm (non-additive)
Annual Quantity	2,226 afy (additive)
Purpose of Use	Municipal Supply
Period of Use	Year round, as needed
Place of Use	City of Lacey approved water service area

Legal Requirements for Approval of Appropriation of Water

The following requirements must be met prior to authorizing the proposed water right:

- **Public Notice**
  Notice of the proposed appropriation was published in *The Olympian* of Olympia, Washington, on December 20 and 27, 2005. No protests were received by Ecology.

- **State Environmental Policy Act (SEPA)**

The subject application is categorically exempt under SEPA (WAC 197-11-305 and WAC 197-11-800(4)) because the instantaneous quantity is less than the 2,250 gpm threshold.

However, the Mitigation Plan submitted by the City of Lacey addresses impacts from six applications for groundwater right that, in sum, exceed the threshold for environmental review. The city, as the lead agency, completed an environmental review for all six water rights and determined on April 8, 2011 that these water rights will not have a significant adverse impact upon the environment and that an Environmental Impact Statement was not required under Chapter 43.21C.030(2)(c). This decision was made after review of:

- Completed Environmental Checklist - dated March 31, 2011,
- Letter from Department of Ecology dated March 18, 2011, and
- City of Lacey Comprehensive Water Rights Mitigation Plan, dated December 3, 2010.

- **Water Resources Statutes and Case Law**
  Chapters 90.03 and 90.44 RCW authorize the appropriation of public water for beneficial use and describe the process for obtaining a water right. Laws governing the water right permitting process are contained in RCW 90.03.250 through 90.03.340. Based on the provisions of RCW 43.21A.690 and RCW 90.03.265, this application has been processed by Aspect Consulting, LLC (Aspect Consulting) under Ecology Cost Reimbursement Agreement No. ASP001 (master contract No. C1000185).

INVESTIGATION

In consideration of this application, Ecology reviewed available documents pertaining to the application's site conditions, projected water demand, the potential effects on surface water bodies, and the potential effect on existing water right holders and established minimum instream flows. This review included information submitted by the applicant, including well construction and testing reports, leakage and surface water depletion analysis, and proposed mitigation strategies, along with pertinent Ecology records, including well logs and water rights records. The review also included reports from multiple investigations characterizing the hydrogeology and water quality of the area, as well as the documents resulting from the watershed planning processes.

A site visit was performed on November 6, 2008. Ecology staff, including Mike Gallagher, led by Julie Rector and Peter Brooks representing Lacey, visited several of Lacey's proposed and existing well sites. Since the site visit, extensive coordination between the Lacey, Ecology, and other project stakeholders has occurred in development of a Comprehensive Water Rights Mitigation Plan, which was prepared by Lacey (updated draft submitted in December 2010).

Regional project stakeholders include the cities of Yelm and Olympia, along with local Indian Tribes, Washington Department of Fish and Wildlife, and residents near Long, Hicks, and Pattison lakes. Coordination between the cities of Olympia, Lacey, and Yelm included joint refinement of a regional groundwater model. The model was used to identify potentially impacted surface waters, and to predict individual and cumulative impacts from additional groundwater pumping. Results of the modeling are the basis for development of the mitigation actions, including those that are jointly proposed for Woodland Creek, Deschutes River, and McAllister Creek basins. In addition, individual mitigation measures are proposed by each city to offset well-specific impacts.

Using this information, we evaluated water availability and potential effects of the proposed appropriation upon existing groundwater and surface water rights, including instream flows, and water quality. Each of the four requirements specified in RCW 90.03.290 were individually examined and findings presented below. Ecology has evaluated this application individually, and in connection with other applications filed by Lacey that are being processed at this time. In addition, Ecology has evaluated this application in the context of other applications filed by the cities of Olympia and Yelm that are being processed at this time. Accordingly, the following investigation focuses on this individual application, but also as appropriate considers and references Lacey's other applications and the Olympia and Yelm applications.

Project Description

The Application for a Water Right submitted by Lacey seeks authorization to withdraw groundwater from three wells, Well Nos. 21, 22, and 23, collectively known as the Madrona Wellfield. The subject application is one of 6 applications addressed in the Mitigation Plan.

The water authorized under the new permits will service the long-term needs of the Lacey and the surrounding Urban Growth Area (UGA). Lacey's current water right portfolio includes 13,572.5 acre-feet (af) in primary (additive) water rights from over 48 permits and certificates, of which 10,311.3 afy are currently on existing wells and available on system. Table 2 is a summary of Lacey's existing water rights portfolio. Previous demand projections predicted a supply deficit would occur by 2006; however, through water right acquisitions, efficiency measures, and administrative restrictions on growth (i.e. Resolution 917), current water supply is projected to meet demand through 2012. In total, the six new permits will provide an additional 7,392 afy. This quantity is expected to fulfill the current estimate for full build out of the UGA and infill within city limits – an approximate 30 to 40 year supply.

Table 2 – City of Lacey's Water Right Portfolio

Source	Water Right Number	Priority Date	Qi in gpm	Qa in afy Additive	Qa in afy Non-Additive
Well No. 1	4578-A	4/26/1962	215	344	-
	G2-20880C	3/20/1973	450	-	240
Well No. 2	5655-A	8/19/1965	600	960	-
Well No. 3	7450-A	3/3/1969	206	330	-
Well No. 4	55-A (B)	9/19/1946	1800	623	-
	G2-23191C	4/19/1974	600	-	320
Well No. 6	G2-27373P(A)	8/13/1986	600	918	49.4
Well No. 7	G2-24351C	11/22/1976	2,150	-	2,775
Well No. 9	G2-25779C	2/10/1981	1,300	21	1027
Well No. 10	G2-25778A	2/10/1981	1,200	22	1649.75
Evergreen Estates	G2-20883C	3/20/1973	700	-	374
McAllister Well	G2-23743C	3/3/1975	500	-	400
	G2-26685	4/18/1985	300	157	-
Madrona Nos. 1	1288-A	2/2/1951	55	30	-

and 2 and 3	1777-A	6/6/1953	300	432	-
	3718A	4/4/1956	350	112	-
	3654-A	3/30/1959	283	452.8	-
	3823-A	7/13/1960	300	480	-
	6320-A	3/19/1968	150	108	-
	G2-20879	3/20/1973	300	-	160
	G2-25778(B)	2/10/1981	500	-	403.25
	G2-25778(C)	2/10/1981	550	-	885
	G2-20878C	3/20/1973	200	-	107
	G2-26623B	11/29/1984	440	132	-
	7450(B)	3/3/1969	920	1320	-
	G2-27373(B)	8/13/1986	200	-	322.6
	G2-25802C	2/24/1981	250	130	-
Pleasant Glade	G2-27372P	8/13/1986	800	-	1290
Hawks Prairie	G2-27371P	8/13/1986	800	1026	264
Beachcrest No. 1	G2-23963C	9/19/1975	250	211.7	-
Beachcrest No. 2	G2-24547C	5/12/1977	250	90	211.7
Beachcrest wellfield	G2-00767C	2/22/1971	20	7.5	-
Nisqually No. 19A	G2-20104C	4/6/1972	350	270	-
Nisqually No. 19C	G2-20882C	3/20/1973	250	-	270
Betti well	G2-27007	8/13/1987	1,000	468.3	-
Well 31 HP #2	G2-30248	5/3/2005	800	1066	
Well 29 (Betti)	G2-30249	4/28/2005	1000**	600	
Well 30 (MC)	G2-30250	5/6/2005	800	1000	
Well 32 (MC)	G2-30251	5/6/2005	1000	1500	
Brewery Wellfield	(numerous)	1937 to 1982	2,172*	761.2*	
Total			**23,911**	**13572.5**	

* The brewery water rights total 6,515 gpm, 2283.53 AFY and are jointly owned by the cities of Lacey, Olympia, and Tumwater. The amounts shown represent Lacey's share of the rights.

**Non-additive to G2-27007

The place of use for all six applications is consistent with the current City of Lacey Water System Comprehensive Plan which is the designated city water service area. The current water system plan was approved by the Department of Health in September 2003 (Gray and Osborne). An update to the water system plan, including updated demand projections, is pending following processing of the above mentioned application(s).

Site and New Source Description

The existing points of withdrawal are located within three individual well buildings, all located in northwest quarter of the northwest quarter of Section 24 in Township 18 North, Range 1 West Willamette Meridian (WM).

A test well (TW-1) was installed and tested in to assess the yield and water quality of the Madrona Wellfield site. Following favorable results, Well No. 21 was installed and tested in February 1996 (PGG 1996). Well No. 21 was completed to a depth of 334 feet below ground surface (bgs) with a 16-inch diameter casing and a 14-inch well screen assembly from 259 to 329. Three intervals in the Qc aquifer are screened with 30- to 150-slot well screen for a total open interval of approximately 32 feet. Similarly, in June 1997 Well No. 22 was completed to a depth of 334 feet below ground surface (bgs) with a 16-inch diameter casing and a 14-inch well screen assembly from 262 to 334 feet bgs. Three intervals in the Qc aquifer are screened 100- to 150-slot well screen for a total open interval of approximately 42 feet. The third well, Well No. 23, was completed in June 2000 to a depth of 338 feet bgs with a 20-inch diameter casing and an 18-inch well screen assembly from 259.5 to 262.5 feet bgs. Two intervals in the Qc aquifer are for a total open interval of approximately 54 feet.

Static water level at the Madrona Wellfield is approximately 216 feet bgs (approximately 37 feet above sea level). Based on the testing completed after construction, each well is rated for a minimum sustainable pumping rate of 1,600 gpm (PGG 1996, 1997, and 2002).

The Madrona Wellfield is located on the uplands west of the McAllister Creek drainage, approximately 2.0 miles south of Interstate 5 in the Madrona Park development, just inside the Nisqually River basin (Water Resource Inventory Area [WRIA] 11) delineation from the Deschutes River basin (WRIA 13).

Hydrogeologic/Hydrologic Assessment

The hydrogeology of the Lacey area upland is defined by four major water bearing stratigraphic units. These units are described in numerous reports, including the three Madrona Wellfield well installation and testing reports (PGG 1996, 1997, and 2002). The Vashon Drift, with its characteristic large thicknesses of stratified sand and gravel, gives rise to the uppermost aquifer in the *recessional outwash (Qvr)* deposits. The Qvr aquifer supports numerous shallow water table lakes and wetlands, and contributes to perennial base flow to creeks and rivers. Below, low permeable Vashon *till* (Qvt) often separates the upper recessional and the underlying advance outwash aquifers. The *advance outwash (Qva)* serves as a significant source of potable water for some smaller municipal and exempt water supply wells. The Qva is often hydraulically confined by the overlying low-permeability Qvt. Few water supply wells are completed in the Qvr due to its limited thickness; however, it is estimated that one half of the potable water in Thurston County is derived from the Qva, where present (Drost et al. 1999).

Below the Vashon Drift sequence is the clay and silts of the interglacial Kitsap formation. This unit typically acts as a regional aquitard, separating the shallow aquifers from the more regionally extensive deeper aquifers.

Underlying the Kitsap formation are deposits from the *"penultimate" glaciation (Qc)*, or more regionally identified as the Double Bluff Drift, which is present throughout most of the WRIA. The Qc aquifer is

typically 15 to 70 feet thick, but has been observed to be in excess of 200 feet thick. The coarse grained layers within the Qc are a heavily utilized water bearing unit throughout the area.

The deepest known major water bearing unit is the *undifferentiated and unconsolidated Quaternary and Tertiary sedimentary units (Qu/TQu)*. Although highly heterogeneous, several different water bearing layers have been identified and developed as water supplies, including several of the wells currently being evaluated. Few wells penetrate the entire thickness of the unconsolidated deposits, so information on thickness or extent of deeper regional water bearing zones is limited.

Groundwater Flow

The groundwater flow system in the Lacey area is generally characterized by recharge of precipitation to the Qvr and downward percolation through the Qvt or directly to the Qva aquifer where the Qvt is absent (PGG 2002). In the shallow Vashon aquifers (Qvr and Qva), groundwater flow directions generally correspond to surface topography – with groundwater divides located near ridgelines, and flow radiating toward marine (Puget Sound) and regional fresh water (McAllister Creek and Nisqually River) discharge points.

Groundwater flow in the intermediate Qc aquifer exhibits similar flow patterns as the overlying Vashon aquifers, but the effect of local surface water drainages is muted. Drost et al. (1999) concluded that deeper groundwater discharges principally to regional discharge features like the McAllister and/or Nisqually River system and Puget Sound. However, similar to the Vashon aquifers, groundwater divides in the Qc aquifer are near topographic ridgelines, with flow directions toward the regional discharge features described above. An analogous flow pattern is observed in the deeper TQu aquifer.

The Madrona Wellfield is completed in the Qc aquifer, encountered from approximately 230 to 332 bgs (approximately 102 feet thick). Testing of the wells following completion indicate an average transmissivity of 1,720,000 gpd/ft (229,947 ft^2/d) and an aquifer storage coefficient of $6x10^{-6}$ (unitless; PGG 2002).

Water Quality

Groundwater in the Qc aquifer has characteristically elevated levels of nitrate. However, all primary and secondary Maximum Concentration Limits (MCL) for drinking water are met.

Water Resource Inventory Area 13

WRIA 13 includes the Deschutes River watershed and several other smaller watersheds, including the Eld, Budd, and Henderson Inlets. The Henderson Inlet watershed contains two major streams – Woodard and Woodland Creek – in addition to a half dozen smaller drainages that emanate from coastal valleys sloping toward Puget Sound. The headwaters of Woodland Creek begin on the Hawks Prairie upland, with a chain of lakes (Hicks, Pattison, and Longs Lakes) and interconnected wetlands. Below the headwaters, Woodland Creek is typically ephemeral, but a large spring below Martin Way provides perennial baseflow to the creek. In addition, several tributaries joining Woodland Creek below the springs also contribute to summer baseflow. Approximately 90% of the Woodland Creek basin falls within Lacey's Urban Growth Area.

Due to the nature of the shallow soils and the generally flat topography of the upper Woodland Creek basin, it is estimated that a majority (80 to 90 percent) of the infiltrated precipitation either discharges

directly to Puget Sound or across the WRIA 11 boundary to McAllister Creek and the Nisqually River system (Clingman 2001).

The WRIA 13 watershed planning process was to *"create a long-range water resource management framework to protect aquatic habitat and provide water for vital community needs."* The key challenge for the watershed planning group, consisting of governmental, tribal, and private entities, was to balance the water needs of a growing region with the imperative to preserve adequate stream flows (WRIA 13 2004b).

Although the draft WRIA 13 Watershed Plan was not finalized or officially adopted by the Planning Unit several recommendations were made, based on the additional data collected during the planning process, regarding how to best implement the three major planning elements – Water Quantity, Water Quality, and Instream Habitat. The availability and appropriation of public water was a central theme to all elements considered.

Minimum Instream Flows – WRIA 13

Chapter 173-513 WAC outlines an instream resources protection program and specifies minimum instream flows for the Deschutes River Basin and WRIA 13. The program effectively limits, and in some cases prohibits, the further issuance of consumptive water rights that could affect flows. The Chapter 173-513 WAC also stipulates that lakes and ponds in WRIA 13 are to be "retained substantially in their natural condition while considering future allocations."

The Chapter 173-513 WAC specifies the Deschutes River, from river mile 41 to the confluence with Capitol Lake, is subject to instream flows and seasonally closed April 15 to November 1. In addition, Woodland Creek and all its tributaries, including Long, Pattison, and Hicks Lake, are closed to further consumptive appropriations, year round. This implies that no consumptive water is available following adoption of Chapter 173-513 WAC (June 24, 1980), unless it is verified that such appropriation would not adversely impact the neighboring closed water body.

Water Resource Inventory Area 11

WRIA 11 is divided into seven subbasins. The subbasins represent surface drainage areas of significant tributaries to the Nisqually River. However, subbasin delineation, similar to the boundaries of the WRIA, often do not correspond with groundwater divides or aquifer boundaries – such as the administrative delineation between the Hawks Prairie upland of WRIA 13 and the McAllister Creek subbasin of WRIA 11.

The Nisqually Tribe and the WRIA 11 Planning Unit completed a Watershed Management Plan in October 2003. The main objective of the plan is to *"develop a comprehensive strategy for balancing competing demands for water, while at the same time preserving and enhancing the future integrity of the watershed."* The scope of the plan was focused on examining and presenting recommendations on five key issues: growth and land use, groundwater resources and supply, water rights, instream flow and surface/groundwater continuity, and water quality.

The WRIA 11 Plan presented several recommendations for processing water rights within WRIA 11. The recommendations include batch processing of water right applications by subbasin, along with filling identified data gaps prior to processing. The Plan also offers 16 possible mitigation strategies for consideration in processing water rights.

Minimum Instream Flows – WRIA 11

Similar to the WRIA 13 instream flow rule described above, Chapter 173-511 WAC outlines an instream resources protection program and specifies minimum instream flows for the Nisqually River Basin and WRIA 11. Most applicable to Lacey's applications are the year-round closure of McAllister Creek and all its tributaries (except Medicine Creek) and Lake Saint Clair. In addition, Chapter 173-511 WAC divides the mainstem Nisqually River into four stream management units (SMU): lower, bypass, middle, and upper reaches. Chapter 173-511 WAC specifies control points (stream gages) for each of the four mainstem SMUs, and specifies minimum instream flows for all months of the year at each control point. The control point for the Lower Reach is located at river mile 4.3, which represents the reach between the influence of the mean annual high tide (at low flow conditions) and the outlet of the Centralia City Light Power Plant (river mile 12.6). In addition, the bypass and middle reaches of the mainstem Nisqually River are closed to further consumptive appropriation from June 1 to October 15.

Flows in the Nisqually River are controlled by the Tacoma Power operated LaGrande Dam and the Centralia City Light operated river diversion near Yelm. These projects are regulated by the Federal Energy Regulatory Commission (FERC) and are required to be operated at a level that ensures sufficient instream flow for fish in the Nisqually River.

In 2001, Ecology completed a study examining instream flows in the lower reach of the Nisqually River. As a surrogate for the control point at RM 4.3, a numerical relationship was developed predicting flows in the lower reach from two upstream USGS gages and the study-specific discharge measurements collected at RM 4.6. Comparison of the numerical relationship to historical data indicate that minimum instream flows in the lower reach have been met much of the time, except for only a couple known failures.

Predicted Impacts to Instream Flows and Closures

Hydrogeologic impacts associated with this application were evaluated through joint-development of a regional groundwater model with all project stakeholders. Based on the original Thurston County groundwater model developed by the United States Geologic Survey (Drost et al. 1999), the groundwater model was originally developed for Olympia for evaluating impacts to surface water bodies near McAllister Springs and Olympia's proposed McAllister Wellfield (Golder 2008). The model was subsequently updated and improved by the cities of Lacey, Olympia, and Yelm to include additional surface water features and refinements in hydrostratigraphy. The cities of Olympia and Yelm also used the updated model to conduct evaluations of their proposed water right applications.

Modeled impacts due to increased pumping in the Lacey uplands are presented in Golder (2008) and in City of Lacey (2010). Aggregated groundwater discharge changes to main hydrologic features due to increased pumping of the Madrona Wellfield are summarized in Table 3 below.

Table 3 – Modeled Impacts from increased withdrawal at Madrona Wellfield (Golder 2008; City of Lacey 2010)

Basin	Maximum Annual Depletion cfs	Maximum Annual Depletion Month	Average Annual Depletion afy
Woodland Creek at Henderson Inlet	0.39	Mar	228
McAllister Creek at Medicine Creek	0.88	Feb-Mar	561
Nisqually River at RM 4.3	0.35	Feb-Mar	220
Deschutes River at Tumwater Falls	0.16	Feb-Mar	84

Cumulative impacts of all six applications under consideration for the City of Lacey, including maximum instantaneous predicted depletions (in cfs) and cumulative annual impacts (in afy) are summarized in Table 4.

Table 4 – City of Lacey's Cumulative Modeled Impacts (City of Lacey 2010)

Basin	Maximum Annual Depletion cfs	Average Annual Depletion afy
Woodland Creek at Henderson Inlet	0.83	486
McAllister Creek at Medicine Creek	1.91	1,232
Nisqually River at RM 4.3	0.82	531
Deschutes River at Tumwater Falls	0.34	179

Cumulative regional impacts, including the proposed withdrawals for the City of Olympia and/or Yelm are presented in Table 5. Positive sign indicate a net gain in discharge.

Table 5 – Cumulative Regional Impacts by Cities of Lacey, Olympia, and Yelm

Basin	Maximum Annual Depletion cfs	Average Annual Depletion afy
Woodland Creek at Henderson Inlet	1.06	631
McAllister Creek at Medicine Creek	+6.72 to 18.72	+7,260
Nisqually River at RM 4.3	6.47	4625
Deschutes River at Tumwater Falls	0.95	258.23

Lacey's Comprehensive Water Rights Mitigation Plan

To address the impacts to instream flows, a Comprehensive Water Right Mitigation Plan (Lacey 2010) was developed in conjunction with project stakeholders and submitted for review. The Mitigation Plan is designed to mitigate for all six subject water right applications. Several of the elements included in the plan are shared amongst the cities of Olympia, Lacey and Yelm, and in the development of the Mitigation Plan Lacey developed collaborative mitigation strategies with the cities of Olympia and Yelm for the Deschutes and Woodland Creek Basins through Interlocal Agreements.

The plan utilizes the benefit of both in-kind (direct replenishment of flow) and out-of-kind (riparian protection and habitat improvements) elements. This is consistent with recommendations for mitigation outlined in the Nisqually Watershed Management Plan (WRIA 11).

Mitigation is proposed in a three phase approach as new water supplies are developed to meet increasing demand. Phase 1 of the mitigation program includes two applications (G2-30248 and G2-30249) necessary to meet Growth Management Act obligations in the near-term. Phase 2 applications (G2-29304 and G2-30251) are projected to meet demand from 2018 - 2026. Phase 3 applications (G2-29165 and G2-30250) will be developed by year 2020 and are anticipated to meet future demand through the next 30 to 40 years.

A summary of mitigation actions proposed by Lacey (2010) by river basin is included in the sections below. Mitigation of regional and application specific impacts for the cities of Olympia and Yelm are summarized in the ROEs for those applications.

Woodland Creek

Offset of impacts to Woodland Creek will include both in-kind and out-of-kind mitigation. Regional In-kind mitigation with the city of Olympia will include groundwater recharge via infiltration of Class A reclaimed water produced at LOTT's Martin Way Reclaimed Water Plant. Location of the infiltration facility is in the Woodland Creek basin, between Goose Pond and Goose Lake at the Woodland Creek Community Park. Infiltration will be phased in to coincide with development of Lacey's and Olympia's permits. Reclaimed water will be infiltrated at a seasonal rate between 0.3 (winter) to 1.3 (summer) million gallons per day (mgd).

The modeled feasibility and effectiveness of infiltration of reclaimed water are presented in PGG (2010). The study indicates that seasonal infiltration of 0.3 to 0.8 mgd would provide an increase in Woodland Creek flow by 0.39 to 0.72 cfs, winter and summer, respectively. However, final infiltration rates will be determined by water quality permitting, and verified through performance monitoring. The cities have proposed to take an adaptive management approach for phasing in mitigation for Phases 1 and 2, and then Phase 3. Data collected during implementation of Phases 1 and 2 of mitigation will be used to further optimize design of the facility by the time Phase 3 water rights will be developed. However, the efficacy of mitigation is not anticipated to be sufficient to offset the Phase 3 summer impacts and Phase 2 and 3 winter impacts.

Specific to predicted impacts to the tri-lakes (Hicks, Pattison, and Long), no in-kind mitigation directly benefiting the surface water bodies is proposed.

Out-of-kind mitigation will include the acquisition of property and/or conservation easements along Woodland Creek to increase the amount of undeveloped protected land along the creek, adding to the 490 existing acres of buffer, parks, and protected open space in the basin. As part of the regional mitigation package, the three cities will jointly purchase approximately 30-acres of undeveloped property in the basin. Separate from the regional out-of-kind mitigation, Lacey will provide additional mitigation in the basin, consisting of a $500,000 commitment for additional restoration projects and/or property acquisition over a ten year period.

McAllister Creek Basin

Regional mitigation in McAllister Creek will be provided by Olympia when it transfers its water rights and current surface water withdrawal of up to 21,969 afy from McAllister Springs to the McAllister Wellfield. The McAllister Wellfield is located about one mile south-southeast of McAllister Springs.

When Olympia ceases diverting water from McAllister Springs and starts withdrawing water from the McAllister Wellfield, the flow in McAllister Creek is predicted to increase by 6.72 to 18.72 cfs, which will offset the predicted impacts from all three cities, including Lacey's predicted impact of 1.91 cfs.

Nisqually River Basin

Lacey's predicted depletion to the Nisqually River system is limited to the lower reach. The lower reach of the Nisqually River is open year round to appropriation, subject to seasonal instream flows at river mile (RM) 4.3.

As stated in the Mitigation Plan, Lacey will discontinue use of its two wells located in the Nisqually Valley. The two wells have associated water rights (G2-20882 and G2-20104C) totaling 600 gpm (Qi) and 270 afy (Qa).

Deschutes River Basin

Impacts to the Deschutes River Basin will be offset through joint regional mitigation measures, which will include both in-kind and out-of-kind elements. During the closed period (April 15 to November 1), impacts will be partially mitigated through the acquisition and retirement of consumptive irrigation water rights. Together, the three cities have purchased 270 af of certificated water rights from two separate irrigation rights which they intent to retire:

1. S2- 00972C (Dillard and Juanita Jenson): 100 afy and 0.50 cfs; and
2. G2-26862G (Ron Smith): 170 afy and 0.67 cfs.

Out-of-kind mitigation is proposed to offset impacts during the non-irrigation season, including land acquisition and habitat restoration. The cities have jointly purchased approximately 200 acres of the Smith Farm located on the upper reach of the Deschutes River. The cities have also identified several riparian and habitat projects that will be completed, including: channel improvements, reestablishment of wetlands, installation of a cribwall to prevent erosion, and planting of several low- and high-density riparian buffers. The restoration and rehabilitation will take several years and is expected to be completed by year 2016.

APPLICATION EVALUATION

This Report of Examination (ROE) evaluates the application based on the conceptual model presented above. To approve the application, Ecology must determine that each of the following four requirements of has been satisfied:

(1) Beneficial Use – the proposed appropriation would be put to a beneficial use;
(2) Availability – water is available for appropriation;

(3) Impairment – the proposed appropriation would not impair existing water rights; and
(4) Public Interest – the proposed appropriation would not be detrimental to the public interest.

Source of Water Proposed for Appropriation

The applicant seeks to withdraw water from three wells located in the northwest quarter of the northwest quarter of Section 24 in Township 18 North, Range 1 West Willamette Meridian (WM). The application requests an appropriation from the Qc aquifer.

Although the Qc aquifer may not be in direct geologic contact with nearby surface water, widespread drawdown effects from pumping of the well may induce increased vertical leakage from shallower aquifers which, in turn, may reduce baseflow contribution to regulated surface water bodies. Consequently, Lacey's application is considered to be in hydraulic continuity and competing for water within the Nisqually and Deschutes River basins, which are limited to further appropriation under Chapters 173-511 WAC and 173-513 WAC, respectively.

Water Availability and Impairment of Flows

Both Chapters 173-511 WAC (Nisqually Basin) and 173-513 WAC (Deschutes Basin) state the purpose of the rules is to retain perennial rivers and streams with instream flows and levels necessary to provide protection for wildlife, fish, scenic-aesthetic, environmental values, recreation, navigation, and water quality.

The rules close portions of the Nisqually and Deschutes Rivers and some other water bodies to further consumptive appropriations and establish specific instream flows on the rivers. Lacey has proposed to use water for municipal supply purposes in a manner that is predicted to deplete flows in both the Deschutes River and Nisqually River basins in periods when the rivers are closed or when they may not meet adopted instream flows.

Stream "closures" are determinations by Ecology under RCW 90.54.020 that water is not *available* for further appropriations. *See Postema v. PCHB*, 142 Wn.2d 68, 95, 11 P.2d 726 (2000). However, a stream closure may, in certain circumstances, be overridden under an exception that authorizes a new appropriation from a closed stream "in those situations where it is clear that overriding considerations of the public interest will be served." (RCW 90.54.020(3)(a). Similarly, under this statute an instream flow can be overridden if "overriding considerations of the public interests are served."

In making a statutory determination of overriding considerations of public interest under RCW 90.54.020(3)(a), the analysis applies three steps:

1. Determine whether and to what extent important public interests would be served by the proposed appropriation. The public interests served may include benefits to the community at large as well as benefits to the river or other environmental resources;
2. Determine whether and to what extent the proposed appropriation would harm any of the public interests (fish, wildlife, scenic, aesthetic, and other environmental and navigational values) protected by the closure and/or any other public interests; and

3. Determine whether the public interests served (as determined in Step 1) clearly override any harm (as determined in Step 2).

The following sections of this report present this three-step OCPI analysis.

Analysis of Public Interests Benefitted by the Water Supply Proposal

Public Water Supply Benefits: When the total package of mitigation measures is considered, the Mitigation Plan proposed by Lacey results in a net ecological benefit for water resources specifically and natural resources generally. The substantial water quantity mitigation provided by joint acquisition of two water rights (Smith and Jensen) benefits the key reaches of the Deschutes River at critical times of the year. For example, water quantity mitigation benefits target the upper and middle reaches of the Deschutes River, whereas the majority of the impacts occur in the lower reach of the river. The few water depletions predicted by modeling occur in less critical areas and in the winter and shoulder seasons that are less critical to the ecological values protected by regulations. In addition, timing of mitigation measures are phased to match development of the water right such that mitigation will occur at the same time or before the corresponding impacts take place.

Lacey's water rights would provide a significant source of public water supply addressing future needs of customers and business served by Lacey. Providing reliable public water supplies that meet the needs of population and economic growth is an important state policy recognized in RCW 90.54.010 and RCW 90.54.020. Lacey's forecast predicts that without the new appropriation Lacey would have an unmet need in excess of 7,200 afy by 2030. The new water supply would provide a measure of water security to Lacey.

McAllister Creek Benefits: While Lacey's water right proposal will result in impacts to McAllister Creek, the overall effect of the combined actions of the three cities will result in greater flows to McAllister Creek. This will provide substantial benefit to the continued restoration of the McAllister Creek Basin.

Deschutes River Benefits: Lacey, in collaboration with the cities of Olympia and Yelm, are offsetting predicted flow depletions in the Deschutes River and significantly enhancing fish and wildlife habitat in the basin using two methods:

- Flow mitigation (in-kind) through acquisition and retirement of irrigation water rights; and
- Land acquisition and habitat restoration (out-of-kind).

As part of a shared mitigation strategy, the cities of Olympia, Lacey and Yelm have purchased a farm (Smith Farm) along with its water right, and the water right from another farm (Jensen Farm), both of which are located in the Deschutes watershed. The cities would retire the water rights and conduct habitat improvement projects on the Smith Farm. The cities have acquired consumptive irrigation water rights that will mitigate predicted impacts by returning water to the river during most of the low-flow closure period. Both water rights total 270 acre feet of water during the irrigation season (May through September). The cities gave higher priority to the acquisition of surface water rights in the upper and middle reaches of the Deschutes River, to ensure that mitigation was in the same reach as, or upstream of, predicted impacts. For Lacey, this approach provides a considerable amount of additional benefit to

the upper and middle reaches of the river, since the majority of Lacey's predicted impacts are in the lower reach.

In addition, the three cities have proposed an out-of-kind mitigation package for the non-irrigation period (October through April) impacts on the Deschutes. The proposed out-of-kind mitigation will result in numerous habitat improvements on the Smith Farm including habitat enhancements to over one mile of mainstem riparian habitat on the Deschutes River, as well as side channel and wetlands enhancements. The Cities propose land acquisition and habitat restoration as the most appropriate strategy for "winter" impacts. These actions can have greater biological benefits during the winter than flow mitigation. For example, in the Deschutes, one of the primary limiting factors for fish in the winter is the availability of off channel rearing habitat and/or large woody debris that provide protection from high main stem flows. In addition, these restoration actions will have year-round benefits and basin wide improvements in water quality.

The Cities have jointly purchased over 200 acres of farmland which is located in the upper reach of the Deschutes River. This property is currently a sheep ranch and has been altered considerably from a natural condition. The property includes Deschutes River frontage, most of the frontage of the outlet channel from Lake Lawrence, and springs that flow via the outlet channel to the Deschutes River. To evaluate the Smith Ranch's potential for water rights mitigation, the cities contracted with Anchor QEA to conduct an acquisition and restoration assessment of the site. Anchor QEA concluded that this site is uniquely situated to provide habitat restoration benefits.

Ecology's October 2008 Draft TMDL report for the Deschutes River recommends riparian plantings, stream channel restoration, reduction of fine sediments, and elimination of animal wastes to reduce temperatures, improve dissolved oxygen levels, and reduce fecal coliform bacteria.

Woodland Creek Benefits: The predicted impacts to Woodland Creek will be addressed with a combination of in-kind and out-of-kind mitigation. In-kind mitigation will include infiltration of Class A reclaimed water produced at LOTT's Martin Way Reclaimed Water Plant. The location of the infiltration facility is in the Woodland Creek Basin, near the Woodland Creek Community Center in Lacey. Reclaimed water will be infiltrated at a seasonal rate between 0.3 (winter) to 0.8 (summer) million gallons per day (mgd). Out-of-kind mitigation will be provided through property acquisition resulting in habitat preservation.

Benefits to the Woodland Creek system include in-kind mitigation through the infiltration of Class A reclaimed water. Flow-related mitigation for all predicted impacts in the Woodland Creek basin (excluding Phase 2 and 3 during winter months) will occur through a regional reclaimed water infiltration facility to be located near the headwaters of Woodland Creek in Lacey. The facility will infiltrate reclaimed water year-round, with the purpose of recharging groundwater that provides base flows to Woodland Creek. The proposed infiltration facility will increase flows in Woodland Creek.

For out-of-kind mitigation, the cities of Lacey and Olympia have purchased approximately 30 acres of undeveloped property in the basin that includes 2,200 feet of Woodland Creek frontage and 650 feet of Fox Creek frontage. Riparian land protection will supplement the available flow mitigation for winter months, and since the benefits will be year-round, this will further increase summer mitigation

Analysis of Public Interests Potentially Harmed by the Proposal

Nisqually River impacts. Lacey's withdrawal of water under all six permits will deplete flows in the Nisqually River by up to 0.82 cfs (531 afy annually). The flow of the Nisqually River is controlled by releases at Alder Dam, and the releases are intended to ensure flows on the river are met and exceeded. Ecology's (2001) analysis indicates that on rare occurrences flows are not being met on the lower reach at RM 4.3. On these rare occasions, up to 0.82 cfs modeled depletion could occur when flows are not met on the river.

Deschutes River Impacts: Lacey's withdrawal of water under all six permits will deplete flows in the Deschutes River during the non-irrigation period (October 1 through April) by up to 0.34 cfs. Flows are not met approximately 25 to 30 percent of days during this period. In addition to the instream flows, the Deschutes River is closed to further appropriation in October. Therefore some depletion will occur when flows are not met or the river is closed to further appropriation. The impacts to the Deschutes River basin in the fall and winter are not being fully mitigated in-kind.

Woodland Creek Impacts: Lacey's withdrawal of water under all six permits will have impacts to Woodland Creek that will largely be mitigated through the discharge and infiltration of reclaimed water in Woodland Park as described above. Modeling has shown that in the dry season, the cities can infiltrate up to 0.8 MGD of reclaimed water to the shallow aquifer compensating for decreased flows in Woodland Creek. In the wet season, only about 0.3 mgd can be infiltrated without causing adverse affects. The reduced amount of infiltration will occur during the wet season when flows in Woodland Creek are not at critical low flow. Woodland Creek is closed year-round and the winter impacts to the creek will not be fully mitigated in-kind.

Tri-Lakes Impacts: Lacey's wells will have impacts on the Tri-Lakes (Hicks, Pattison, and Long Lakes) with a potential maximum decrease of less than one inch in lake levels. The lakes have a natural yearly variation of 0.5 to 4 feet. Whereas the impacts are small, the lakes are closed to further appropriation, and are not being fully mitigated in-kind.

Summary of OCPI Analysis

The conclusion of the OCPI analysis can only be reached by weighing the potential benefits and harms to the public interest. When all of the public interest benefits and harmed are compared, it becomes evident that the potential benefits clearly outweigh the potential harms. Although the Mitigation Plan provides in-kind mitigation in the form of purchased existing water rights, there are small depletions of the Deschutes River, Nisqually River, Tri-Lakes, and Woodland Creek that cannot be mitigated in-kind. These small depletions are the only public interest potential harms that have been identified in this evaluation. The package of in-kind and out-of-kind mitigation offered by the three cities and the Nisqually Indian Tribe will result in net ecological benefit and provide significant public health, safety and welfare benefits.

Lacey (together with Olympia and Yelm) proposes in-kind mitigation that addresses the majority of surface water depletions. The water quantity mitigation provided by acquisition of water rights (Smith and Jensen), along with reclaimed water infiltration, benefits the key reaches of water bodies at critical

times of the year. In addition, water quantity mitigation benefits target the upper and middle reaches of the Deschutes River, whereas the impacts are centered in the lower reach of the river.

Impacts to McAllister Creek will be mitigated in-kind by Olympia moving their surface water diversion to a wellfield which will increase flows to McAllister Creek.

Although there will be impacts to the flows in the lower reach of the Nisqually River, the river flows are controlled by the city of Tacoma as required under its FERC license. Therefore, these mandated flows result in the Nisqually River rarely falling below the established instream flows.

The out-of-kind mitigation will improve environmental conditions in both the Woodland Creek and Deschutes watersheds. This includes mainstem, side channel, and wetland habitat enhancements in the Deschutes to benefit fishery and water quality and habitat protections in Woodland Creek to benefit fishery and water quality. The few unmitigated impacts to flow on the Deschutes River are during the closure period and are minor relative to the habitat, water quality, and flow enhancement benefits of the out-of-kind habitat restoration.

Impacts to the Tri-Lakes are small. Unmitigated impacts to Woodland Creek occur during the wetter season and will be compensated through out-of-kind mitigation by the purchase of land and riparian habitat in the watershed.

In summary, the public interest benefits of the subject application requested by Lacey and the five additional applications requested by Lacey, along with the water right applications requested by Olympia and Yelm, override any public interest detriments associated with the subject application and with the three cities' new water supply and change of source projects.

Impairment Considerations

No increase in instantaneous pumping rate is requested. However, analysis presented in the Hydrogeologic Evaluation of Well No. 23 (PGG 2002) examines the interference drawdown from pumping the Madrona Wellfield on the closet Qc water supply well(s) – Washington Water Company's Rolling Firs Well No. 1 and 2, located approximately 1,800 and 2,200 feet northwest of Madrona Park. Based on this analysis, the interference drawdown from pumping of all three Madrona Wellfield wells at the full permitted instantaneous rate (4,798 gpm) is estimated at approximately 4.5 feet; a small percentage of the estimated 37 feet of available drawdown.

In addition to the wells evaluated above, Ecology's database was queried for additional well logs within a 2,200-foot radius of the subject application. Results of the search indicate one possible exempt water supply well completed at a depth of 230 to 332 feet bgs (inferred Qc aquifer elevation). Based on the distance –drawdown analysis presented in PGG (2002), no impairment, as defined by WAC 173-150, is expected to occur with full use of the permitted quantities.

Wells completed in the Qc are separated from the Qva aquifer by a thick (locally estimated at over 100 feet) aquitard. This unit greatly limits the hydraulic connection between the Qc and overlying Qva aquifer. Therefore, impairment of wells completed in shallower aquifers is not expected to occur.

Beneficial Use

In accordance with RCW 90.54.020(1), the proposed appropriation for municipal use represents a beneficial use of water.

Detailed planning on how to deliver and manage water in Lacey's water service area will be presented in the update to the Comprehensive Water System Plan. The water will be used at rates consistent with established municipal demand in Western Washington, including all standards required in the Department of Health's Water Use Efficiency Program.

Public Interest Considerations

The final test pertaining to the granting of a water right is the requirement that the appropriation not be detrimental to the public interest. The effects of the appropriation on the public interest are analyzed in the availability section above, where it was concluded that overriding consideration of public interest clearly support approving the application.

RECOMMENDATIONS

Based on the above investigation, I recommend that this request for a water right be approved in the amounts and within the limitations listed below and subject to the provisions listed above.

Purpose of Use and Authorized Quantities

The amount of water recommended is a maximum limit and the water user may only use that amount of water within the specified limit that is reasonable and beneficial:

2,000 gpm (non-additive)
2,226 acre-feet per year (additive)
Municipal Supply

Point of Withdrawal
NW¼, NW¼, Section 24, Township 18 North, Range 1 West WM

Place of Use
As described on Page 1 of this Report of Examination.

Report by Tyson D. Carlson, LHG, Aspect Consulting, LLC *Date*

Phil Crane 2/16/2012

Reviewed by Philip Crane, Water Resources, SWRO *Date*

If you need this publication in an alternate format, please call Water Resources Program at (360) 407-6600. Persons with hearing loss can call 711 for Washington Relay Service. Persons with a speech disability can call 877-833-6341.

REFERENCES

City of Lacey 2010. *Comprehensive Water Rights Mitigation Plan*. Updated December 2010.

Clingman, T. 2001. *WRIA 13 Initial Assessment, Henderson Inlet Watershed*. Thurston County Water and Waste Management. March, 2001.

Drost, B.W., Turney, G.L., Dion, N.P., and Jones, M.A., *Conceptual Model and Numerical Simulation of the Ground-Water Flow System in the Unconsolidated Sediments of Thurston County, Washington.* U.S. Geological Survey Water Resources Investigation Report 99-4165, 1999.

Economic and Engineering Services, Inc. 1995. *City of Lacey, Wellhead Protection Plan*. August, 1995.

Ecology 2001. *Flow Investigation of the Nisqually River Lower Reach, Thurston County, Washington*. Publication No. 01-11-015. November 2001.

Gray and Osborne 2003. *City of Lacey Water System Comprehensive Plan*. Prepared for City of Lacey. Month, Day 2003.

Golder Associates 2003. *Nisqually Watershed Management Plan*. Prepared for the Nisqually Indian Tribe and WRIA 11 Planning Unit. October 31, 2003.

Golder 2007. *McAllister Groundwater Model Updates*. Prepared for the Cities of Yelm and Lacey. November 10, 2007.

Golder 2008. *Groundwater Modeling of Madrona and Evergreen Estates Well Water Right Applications*. Prepared for City of Lacey. February 15, 2008.

Pacific Groundwater Group 1996. *Results of Well Installation and Testing, Lacey Production Well C at Madrona Park*. Prepared for City of Lacey. September 11, 1997.

Pacific Groundwater Group 1997. *Hydrogeologic Evaluation of City of Lacey Well A at Madrona Park*. Prepared for City of Lacey. April 1, 1996.

Pacific Groundwater Group 2002. *Hydrogeologic Evaluation of Lacey Production Well 23 at Madrona Park*. Prepared for City of Lacey. January 29, 2002.

Pacific Groundwater Group 2010. *Woodland Creek Reclaimed Water Infiltration Facility Analyses*. Prepared for City of Lacey. September 2010.

Watershed Professionals Network (WPN) 2002a. *Nisqually River Level I Watershed Assessment (WRIA 11)*. Prepared for Nisqually Watershed Planning Group. March 2002

Watershed Professionals Network (WPN) 2002b. *Nisqually River Level I Watershed Assessment (WRIA 11), Summary Report*. Prepared for Nisqually Watershed Planning Group. July 2002.

WRIA 13 Watershed Planning Committee 2004a. *WRIA 13 Watershed Assessment*. Revised Draft. March, 2004.

WRIA 13 Watershed Planning Committee 2004b. *WRIA 13 Watershed Plan*. Revised Draft. October 15, 2004.