

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

PERMIT

TO APPROPRIATE PUBLIC WATERS OF THE STATE OF WASHINGTON

- Surface Water** (Issued in accordance with the provisions of Chapter 117, Laws of Washington for 1917, and amendments thereto, and the rules and regulations of the Department of Ecology.)
- Ground Water** (Issued in accordance with the provisions of Chapter 263, Laws of Washington for 1945, and amendments thereto, and the rules and regulations of the Department of Ecology.)

PRIORITY DATE April 30, 1993	APPLICATION NUMBER G2-28830	PERMIT NUMBER G2-28830	CERTIFICATE NUMBER
---------------------------------	--------------------------------	---------------------------	--------------------

NAME Greg and Kendra Pelland/Pleasant Acres			
ADDRESS (STREET) 16516 119th Avenue Court East	(CITY) Puyallup	(STATE) Washington	(ZIP CODE) 98374-9999

The applicant is, pursuant to the Report of Examination which has been accepted by the applicant, hereby granted a permit to appropriate the following described public waters of the State of Washington, subject to existing rights and to the limitations and provisions set out herein.

PUBLIC WATERS TO BE APPROPRIATED

SOURCE A well
TRIBUTARY OF (IF SURFACE WATERS)

MAXIMUM CUBIC FEET PER SECOND	MAXIMUM GALLONS PER MINUTE 40	MAXIMUM ACRE-FEET PER YEAR 4
QUANTITY, TYPE OF USE, PERIOD OF USE 4 acre-feet per year	Multiple domestic supply	Year-round, as needed

LOCATION OF DIVERSION/WITHDRAWAL

APPROXIMATE LOCATION OF DIVERSION--WITHDRAWAL 900 feet north and 550 feet west of the center of Section 30.
--

LOCATED WITHIN (SMALLEST LEGAL SUBDIVISION) SE $\frac{1}{4}$ NW $\frac{1}{4}$	SECTION 30	TOWNSHIP N. 17	RANGE, (E. OR W.) W.M. 3E	W.R.I.A. 11	COUNTY Pierce
--	---------------	-------------------	------------------------------	----------------	------------------

RECORDED PLATTED PROPERTY

LOT 7	BLOCK	OF (GIVE NAME OF PLAT OR ADDITION) Pleasant Acres
----------	-------	--

LEGAL DESCRIPTION OF PROPERTY ON WHICH WATER IS TO BE USED

That portion of the west 433 feet of the east 823 feet of the southeast quarter of the northwest quarter of Section 30, T. 17 N., R. 3 E.W.M. Lying north of Allen Road, Pierce County, Washington.

DESCRIPTION OF PROPOSED WORKS

A well 6" x 110' deep.

DEVELOPMENT SCHEDULE

BEGIN PROJECT BY THIS DATE: January 1, 1995	COMPLETE PROJECT BY THIS DATE: January 1, 1996	WATER PUT TO FULL USE BY THIS DATE: January 1, 1997
--	---	--

PROVISIONS

Installation and maintenance of an access port as described in WAC 173-160-355 is required. An air line and gauge may be installed in addition to the access port.

All water wells constructed within the State shall meet the minimum standards for well construction and maintenance as provided under RCW 18.104, Washington Water Well Construction Act of 1972, and Chapter 173-160 WAC, Minimum Standards for Construction and Maintenance of Wells.

In accordance with WAC 173-160-205, wells shall not be located within certain minimum distances of potential sources of contamination. These minimum distances shall comply with local health regulations, as appropriate. In general, wells shall be located at least 100 feet from a sewer, septic tank, privy, or other source of contamination. Wells shall not be located within 1,000 feet of a solid waste landfill.

"Upon completion of construction, a 4-hour pump test shall be conducted on this well(s) at the proposed rate of withdrawal, following the procedures outline by the enclosed DOH guidelines. Results of this test shall be submitted the Department of Ecology prior to filing proof of appropriation. The instantaneous rate authorized under the resulting certificate may be reduced to reflect the production capacity of these wells, or to protect existing rights."

The Permittee is advised that notice of proof of appropriation of water (under which the final certificate of water right is issued) should not be filed until the permanent diversion facilities have been installed, and the system is currently in use. This includes installation of a mainline system capable of delivering the recommended quantity of water to an existing or proposed distribution system within the area to be served, and fulfillment of all other terms of this permit.

This well shall be cased and permanently sealed to a minimum depth of 18 feet below land surface. Such sealing shall be performed in accordance with the provisions and standards of Chapter 173-160-265 WAC (Minimum Standards for Construction and Maintenance of Water Wells).

An approved metering device shall be installed and maintained in accordance with RCW 90.03.360, WAC 508-64-020 through -040. Meter readings shall be recorded at least monthly.

This permit shall be subject to cancellation should the permittee fail to comply with the above development schedule and/or fail to give notice to the Department of Ecology on forms provided by that Department documenting such compliance.

Given under my hand and the seal of this office at Olympia, Washington,

this 7th day of June, 19 94.

Mary Riveland, Director

Department of Ecology

ENGINEERING DATA

OK [Signature]

by Gale Blomston