

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

PERMIT

TO APPROPRIATE PUBLIC WATERS OF THE STATE OF WASHINGTON

Surface Water (Issued in accordance with the provisions of Chapter 117, Laws of Washington for 1917, and amendments thereto, and the rules and regulations of the Department of Ecology.)

Ground Water (Issued in accordance with the provisions of Chapter 263, Laws of Washington for 1945, and amendments thereto, and the rules and regulations of the Department of Ecology.)

PRIORITY DATE January 21, 1991	APPLICATION NUMBER G2-28007	PERMIT NUMBER G2-28007 P	CERTIFICATE NUMBER
-----------------------------------	--------------------------------	-----------------------------	--------------------

NAME Harbor Water Company, Inc.			
ADDRESS (STREET) Post Office Box 336	(CITY) Gig Harbor	(STATE) Washington	(ZIP CODE) 98335-0336

The applicant is, pursuant to the Report of Examination which has been accepted by the applicant, hereby granted a permit to appropriate the following described public waters of the State of Washington, subject to existing rights and to the limitations and provisions set out herein.

PUBLIC WATERS TO BE APPROPRIATED

SOURCE
A well

TRIBUTARY OF (IF SURFACE WATERS)

MAXIMUM CUBIC FEET PER SECOND	MAXIMUM GALLONS PER MINUTE 125	MAXIMUM ACRE-FEET PER YEAR 200
-------------------------------	-----------------------------------	-----------------------------------

QUANTITY, TYPE OF USE, PERIOD OF USE 160 acre-feet per year (Primary) 40 acre-feet per year (Supplemental)	Multiple domestic supply	Year-round, as needed
--	--------------------------	-----------------------

LOCATION OF DIVERSION/WITHDRAWAL

APPROXIMATE LOCATION OF DIVERSION-WITHDRAWAL
800 feet east and 190 feet south of the center of Section 30.

LOCATED WITHIN (SMALLEST LEGAL SUBDIVISION) NW $\frac{1}{4}$ SE $\frac{1}{4}$	SECTION 30	TOWNSHIP N. 22	RANGE, (E. OR W.) W.M. 1E	W.R.I.A. 15	COUNTY Pierce
--	---------------	-------------------	------------------------------	----------------	------------------

RECORDED PLATTED PROPERTY

LOT	BLOCK	OF (GIVE NAME OF PLAT OR ADDITION)
-----	-------	------------------------------------

LEGAL DESCRIPTION OF PROPERTY ON WHICH WATER IS TO BE USED

Area served by Harbor Water Company, Inc.

DESCRIPTION OF PROPOSED WORKS

Existing 8" x 188' drilled well, equipped with a 5 horsepower submersible pump discharging 125 gpm.

DEVELOPMENT SCHEDULE

BEGIN PROJECT BY THIS DATE: Started	COMPLETE PROJECT BY THIS DATE: June 1, 1994	WATER PUT TO FULL USE BY THIS DATE: June 1, 1995
--	--	---

6/1/2000
6/1/2005 6/1/2010

PROVISIONS

The access port shall be maintained at all times on the well(s).

An approved metering device shall be installed and maintained in accordance with RCW 90.03.360, WAC 508-64-020 through -040. Meter readings shall be recorded at least monthly.

Water levels shall be measured and recorded using a consistent methodology, in accordance with accepted industry standards. Such measurements shall be made at least monthly. The length of the pumping period or recovery period prior to each measurement shall be constant, and shall be included in the record.

"A summary of the previous years monthly water level data and monthly totals of water pumped for this well, shall be submitted to Ecology's Southwest Regional office annually during the month of February, or more frequently if requested by Ecology."

The Water Resources Act of 1971 specifies certain criteria regarding utilization and management of the waters of the state in the best public interest. Use of water may be subject to regulation at certain times, based on the necessity to maintain water quantities sufficient for preservation of the natural environment.

The Permittee is advised that notice of proof of appropriation of water (under which the final certificate of water right is issued) should not be filed until the permanent diversion facilities have been installed, and the system is currently in use. This includes installation of a mainline system capable of delivering the recommended quantity of water to an existing or proposed distribution system within the area to be served.

This permit is subject to the implementation of the minimum requirements established in the Interim Guidelines for Public Water Systems Regarding Water Use Reporting, Demand Forecasting Methodology and Conservation Programs, July 1990.

Under RCW 90.03.005 and 90.54.020(6), conservation and improved water use efficiency must be emphasized in the management of the states water resources, and must be considered as a potential new source of water. Accordingly, as part of the terms of this permit, the applicant shall prepare and implement a water conservation plan approved by Department of Health. The standards for such a plan may be obtained from either the Department of Health or the Department of Ecology.

This permit shall be subject to cancellation should the permittee fail to comply with the above development schedule and/or fail to give notice to the Department of Ecology on forms provided by that Department documenting such compliance.

Given under my hand and the seal of this office at Olympia, Washington,

this 23rd day of October, 19 92.

Fred Olson, Acting Director
Department of Ecology

ENGINEERING DATA

OK AB

by Gale Blomston