

Report of Examination on Ground Water

Received date November 17, 1970 Date of exam February 2, 1971 Appl. No. 11387
Name Howard B. Herrett Address P. O. Box 34, Sequim, WA
Type of works A well Dimensions 6" x 110'
Progress of works Well drilled and capped (complete)
Quantity applied for 10 g.p.m. acre-feet per year
Legal sub. ~~NW 1/4~~ Sec. 29 Twp 30 N. Rge 3 W. County Clallam
Use Group domestic supply
Irrigation-acreage Present Planned Feasible
Municipal Population as of
Industrial
Time pump will be operated Continuously

Other water rights appurtenant to this land Surface Water Cert. #1157 for domestic supply on an existing home.
Proximity to existing works, springs, wells, or streams Wayne Anderson, east 1,200'; Roy Smith, northwest approx. 350', and Merlin Valeski (G.W.C. #5261), north 400'.

Area Sub-area Zone

RECOMMENDATIONS

Approved for 10 g.p.m. 8 acre-feet per year, subject to existing water rights. (1 acre-foot 325,850 gallons.)

The installation of an access port as described in attached Ground Water Bulletin No. 1 shall be required prior to issuance of final certificate of water right. The applicant may, for his own convenience, wish to install an airline and gage in addition to the access port.

It is unknown at this time the total number of lots to be served by this well.

The annual recommended quantity of 8 acre-feet is based on pumping this well at ten (10) gallons per minute for up to 50 percent of the time.

Prior to issuance of certificate, a review of the applicant's project shall be made such that any necessary modifications can be made.

Applicant is advised that notice of proof of appropriation of water (under which final certificate of water right issues) should not be filed until the permanent diversion facilities have been installed together with a mainline system capable of delivering the recommended quantity of water to an existing or proposed distribution system within the area to be served.

Signed at Olympia, Washington
this 7 day of April, 1971.


DEAN WOOD, Water Resources Inspector
Department of Ecology

GW 11387

(page 2)