

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

REPORT OF EXAMINATION
TO APPROPRIATE PUBLIC WATERS OF THE STATE OF WASHINGTON

SURFACE WATER

GROUND WATER

APPLICATION NO. G2-21580	PRIORITY DATE OF APPLICATION October 29, 1973
-----------------------------	--

NAME MERLE G. KEHN			
ADDRESS (STREET): 12542 Champion Dr	(CITY) Olympia	(STATE) Washington	(ZIP CODE) 98502

PUBLIC WATERS TO BE APPROPRIATED

SOURCE
well

TRIBUTARY OF (IF SURFACE WATERS)

MAXIMUM CUBIC FEET PER SECOND	MAXIMUM GALLONS PER MINUTE 20	MAXIMUM ACRE-FEET PER YEAR
-------------------------------	----------------------------------	----------------------------

QUANTITY, TYPE OF USE, PERIOD OF USE
1 acre-foot per year group domestic supply continuously

LOCATION OF DIVERSION/WITHDRAWAL

APPROXIMATE LOCATION OF DIVERSION/WITHDRAWAL
500 feet east and 175 feet north from the south quarter corner of Sec. 12

LOCATED WITHIN (SMALLEST LEGAL SUBDIVISION) C. H. Hale D.L.C. No. 42 within SE/4	SECTION 12	TOWNSHIP N. 18	RANGE, (E. OR W.) W. W. 2 W.	W.R.I.A. 1A	COUNTY Thurston
--	---------------	-------------------	---------------------------------	----------------	--------------------

RECORDED PLATTED PROPERTY

LOT	BLOCK	OF (GIVE NAME OF PLAT OR ADDITION)
-----	-------	------------------------------------

LEGAL DESCRIPTION OF PROPERTY WATER TO BE USED ON

That portion of Hale D.L.C. No. 42, Sec. 12, T. 18 N., R. 2 W.W.M., described as follows:
beginning at a point 1693.38 feet east and 983.97 feet south of the northeast corner of
Sebree's Addition to Olympia as recorded in Vo. 3 of plats, Page 81; thence south 88°20'
east 120 feet; thence south 80 feet to the northerly margin of county road known as Pearce
Road; thence north 88°20' west along said northerly margin of road 120 feet; thence north
80 feet to point of beginning; EXCEPT the west 30 feet for county road known as N. Wilson St.

(SEE REVERSE SIDE)

REPORT OF EXAMINATION

DESCRIPTION OF PROPOSED WORKS

wall - 6" x 42'

DEVELOPMENT SCHEDULE

BEGINNING DATE	COMPLETION DATE	DATE COMPLETE APPLICATION OF WATER TO BE MADE
Started	Completed	March 1, 1976

PROVISIONS AND RECOMMENDATIONS

This application is for the purpose of obtaining a water supply for a group domestic water system consisting of 2 services.

For a development of this magnitude and nature in this locale, 450 gallons per day per service will meet the water demand of each service. For 2 services, this amounts to 1.0 acre-feet per year.

Use of the waters to be appropriated under this application will be for a public water supply. State Board of Health rules require every owner of a public water supply to obtain written approval from the Assistant Secretary, Health Services Division prior to any new construction or alterations of a public water supply.

The installation of an access port as described in attached Ground Water Bulletin No. 1 shall be required prior to issuance of final certificate of water right. The applicant may, for his own convenience, wish to install an airline and gage in addition to the access port.

Owing to the proximity of neighboring wells, the applicant is reminded of his responsibility toward same and advised that he may be required to regulate his withdrawal and pumping rate if existing rights are injuriously affected.

Applicant is advised that notice of proof of appropriation of water (under which final certificate of water right issues) should not be filed until the permanent diversion facilities have been installed together with a mainline system capable of delivering the recommended quantity of water to an existing or proposed distribution system within the area to be served.

Accordingly, this application may be approved for 20 gallons per minute on a continuous basis, not to exceed 1 acre-feet annually.

Signed at Olympia, Washington
this 17 day of March, 1975.


RICHARD S. CARTER, Resources Management
Department of Ecology

Report of Examination on Ground Water

Received date 10-29-73 Date of exam. 2-21-74 Appli. No. G 2-21580
Name Merle G. Kehn Address 12542 Champion Dr. Olympia, WA 98502
Type of works Well Dimensions 6" X 42'
Progress of works complete, in use
Quantity applied for 20 g.p.m. 1 acre-feet per year
SW $\frac{1}{4}$ SE $\frac{1}{4}$ within the C. H. Hale D.L.C.
Legal sub. No. 42 Sec. 12 Twp. 18 Rge. 2 W County Thurston
Use group domestic supply

Irrigation-acreage: Present — Planned — Feasible —

Municipal: Population — as of —

Industrial —

Time pump will be operated continuously

Other water rights appurtenant to this land none of record

Proximity to existing works, springs, wells, or streams J. Wakefield, - NE - 100';

Mrs. B. F. Good - NW - 120'; Jehovah's Witnesses Church - W - 250'

Area — Sub-area — Zone —

RECOMMENDATIONS

Approved for 20 g.p.m. 1 acre-feet per year, subject to existing water rights. (1 acre-foot 325,850 gallons.)

new duplex (2 story) - 3/4 HP 50d

20.00

C.D.W.-1

group

2 services

450

2 services

1.0

Proximity proviso.

20 g.p.m.

1 A.F. / yr.