STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

REPORT OF EXAMINATION
TO APPROPRIATE PUBLIC WATERS OF THE STATE OF WASHINGTON

☐ Surface Water. (Issued in accordance with the provisions of Chapter 117, Laws of Washington for 1917, and amendments thereto, and the rules and regulations of the Department of Ecology.)

☒ Ground Water (Issued in accordance with the provisions of Chapter 263, Laws of Washington for 1945, and amendments thereto, and the rules and regulations of the Department of Ecology.)

PRIORITY DATE	APPLICATION NUMBER	PERMIT NUMBER	CERTIFICATE NUMBER
February 28, 1979	G 2-25148		

NAME
THOMAS J. FRANCE

ADDRESS (STREET)	(CITY)	(STATE)	(ZIP CODE)
2229 South Bay Road	Olympia	Washington	98506

PUBLIC WATERS TO BE APPROPRIATED

SOURCE
well

TRIBUTARY OF (IF SURFACE WATERS)

MAXIMUM CUBIC FEET PER SECOND	MAXIMUM GALLONS PER MINUTE	MAXIMUM ACRE-FEET PER YEAR
	30	3.5

QUANTITY, TYPE OF USE, PERIOD OF USE		
1 acre-foot per year	domestic supply	continuously
2.5 acre-feet per year	irrigation of 1.25 acres	May 1 to October 1

LOCATION OF DIVERSION/WITHDRAWAL

APPROXIMATE LOCATION OF DIVERSION—WITHDRAWAL
1000 feet east and 1100 feet north from the West Quarter corner of Section 7.

LOCATED WITHIN (SMALLEST LEGAL SUBDIVISION)	SECTION	TOWNSHIP N.	RANGE, (E. OR W.) W.M.	W.R.I.A.	COUNTY
SW¼NW¼	7	18	1 W	13	Thurston

RECORDED PLATTED PROPERTY

LOT	BLOCK	OF (GIVE NAME OF PLAT OR ADDITION)

LEGAL DESCRIPTION OF PROPERTY ON WHICH WATER IS TO BE USED

That part of the SW¼NW¼ of Section 7, T. 18 N., R. 1 W.W.M., lying westerly of county road known as South Bay Road and north and east of a line described as beginning at a point on the north line of said SW¼NW¼, south 87°08'59" east 874.28 feet from its northwest corner; running thence south 2°58'01" west 263.3 feet and south 87°08'59" east 239.62 feet to the westerly margin of said South Bay Road; EXCEPT that part lying northerly and easterly of the south and west boundaries of tract conveyed to Paul Bradford Carey by deed dated December 23, 1939 and recorded under File No. 328975.

DESCRIPTION OF PROPOSED WORKS

Well - 8" x 41'
½ HP jet pump
300 gallon pressure tank
Hose bibs with garden sprinklers

DEVELOPMENT SCHEDULE

BEGIN PROJECT BY THIS DATE:	COMPLETE PROJECT BY THIS DATE:	WATER PUT TO FULL USE BY THIS DATE:
Started	Complete	March 1, 1980

PROVISIONS

This application was completed by Mr. Thomas J. France in this office on February 28, 1979, and was published in the Daily Olympian on April 2nd and 9th, 1979. There were no objections to this application during the 30 day protest period.

I field examined this application with assistance from Mr. and Mrs. France on May 9, 1979. The well and home have been in use for over 30 years. Mr. and Mrs. France assured me the irrigation portion of this application has been completed. This is a rural area of medium density population, the nearest homes being less than ¼ mile from the France residence. There is an access port on this well.

Normal annual water demand for domestic supply in this area is 1 acre-foot per year.

Normal annual irrigation water demand in this climatic region is 2 acre-feet per year per acre. The 1.25 acres found feasible to irrigate will require 1.50 acre-feet per year.

I recommend this application be approved for 30 gallons per minute and 1 acre-foot per year for domestic supply to one residence.

An additional 1.5 acre-feet per year is recommended for the irrigation of 1.25 acres, during irrigation season.

The $5.50 permit fee is based on these types of water use as outlined in the State Water Code.

The access port on this well shall be maintained at all times.

The portion of this authorization relating to irrigation is classified as a Family Farm Permit in accordance with Initiative Measure No. 59.

Owing to the proximity of neighboring wells, the applicant is reminded of his responsibility toward same and advised that he may be required to regulate his withdrawal and pumping rate if existing rights are injuriously affected.

Signed at Olympia, Washington,
this 23rd day of May 1979.

Jon Pace
Department of Ecology

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

5-9-79

REPORT OF EXAMINATION
TO APPROPRIATE PUBLIC WATERS OF THE STATE OF WASHINGTON

☐ Surface Water (Issued in accordance with the provisions of Chapter 117, Laws of Washington for 1917, and amendments thereto, and the rules and regulations of the Department of Ecology.)

☒ Ground Water (Issued in accordance with the provisions of Chapter 263, Laws of Washington for 1945, and amendments thereto, and the rules and regulations of the Department of Ecology.)

PRIORITY DATE	APPLICATION NUMBER	PERMIT NUMBER	CERTIFICATE NUMBER
2-28-79	G2-25148		

NAME THOMAS J. FRANCE

ADDRESS (STREET)	(CITY)	(STATE)	(ZIP CODE)
2229 So. Bay Rd.	OLYMPIA	WA.	98506

PUBLIC WATERS TO BE APPROPRIATED

SOURCE WELL

TRIBUTARY OF (IF SURFACE WATERS)

MAXIMUM CUBIC FEET PER SECOND	MAXIMUM GALLONS PER MINUTE	MAXIMUM ACRE-FEET PER YEAR
	30	3.5

QUANTITY, TYPE OF USE, PERIOD OF USE

1 AFT/YR DOMESTIC SUPPLY CONTINUOUSLY
2.5 AFT/YR IRRIGATION OF 1.25 ACRES MAY 1 TO OCT. 1

LOCATION OF DIVERSION/WITHDRAWAL

APPROXIMATE LOCATION OF DIVERSION–WITHDRAWAL

1000' E. + 1100' N. FROM THE W¼ CORNER, SEC. 7

LOCATED WITHIN (SMALLEST LEGAL SUBDIVISION)	SECTION	TOWNSHIP N.	RANGE, (E. OR W.) W.M.	W.R.I.A.	COUNTY
SW¼ NW¼	7	18	1 W	13	THURSTON

RECORDED PLATTED PROPERTY

LOT	BLOCK	OF (GIVE NAME OF PLAT OR ADDITION)

LEGAL DESCRIPTION OF PROPERTY ON WHICH WATER IS TO BE USED

USE LEGAL ON APPLICATION

DESCRIPTION OF PROPOSED WORKS

WELL - 8" X 47' HOSE BIBS WITH GARDEN SPRINKLERS
½ HP JET PUMP
300 GALLON PRESSURE TANK

DEVELOPMENT SCHEDULE

BEGIN PROJECT BY THIS DATE:	COMPLETE PROJECT BY THIS DATE:	WATER PUT TO FULL USE BY THIS DATE:
STARTED	COMPLETE & IN USE	2-28-80

PROVISIONS

THIS APPLICATION WAS COMPLETED BY MR. THOMAS J. FRANCE IN THIS OFFICE ON FEBRUARY 28, 1979, AND WAS PUBLISHED IN THE DAILY OLYMPIAN ON APRIL 2ND AND 9TH, 1979. THERE WERE NO OBJECTIONS TO THIS APPLICATION DURING THE 30 DAY PROTEST PERIOD.

I FIELD EXAMINED THIS APPLICATION WITH ASSISTANCE FROM MR. & MRS. FRANCE ON MAY 9, 1979. THE WELL AND HOME HAVE BEEN IN USE FOR OVER 30 YEARS. MR. & MRS. FRANCE ASSURED ME THE IRRIGATION PORTION OF THIS APPLICATION HAS BEEN COMPLETED. THIS IS A RURAL AREA OF MEDIUM DENSITY POPULATION, THE NEAREST HOMES BEING LESS THAN ½ MILE AWAY FROM THE PROPOSED RESIDENCE. THERE IS AN ACCESS PORT ON THIS ACCESS.

NORMAL ANNUAL WATER DEMAND FOR DOMESTIC SUPPLY IN THIS AREA IS 1 AFT/YR.

NORMAL ANNUAL IRRIGATION WATER DEMAND IN THIS CLIMATIC REGION IS 2 AFT/ACRE. THE 1.25 ACRES DEMAND PERMITS TO THE PROPOSED WELL REQUIRES 1.50 AFT/YR.

I RECOMMEND THIS APPLICATION BE APPROVED for 30 g.p.M. MAXIMUM for DOMESTIC SUPPLY FOR ONE RESIDENCE.

AN ANNUAL 1.5 AFT/YR IS RECOMMENDED for THE IRRIGATION OF 1.25 ACRES, DURING THE MONTHS OF [illegible] THIS IS BASED ON [illegible] TYPES OF [illegible] GROWN IN [illegible]

A.D.
H
M