

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

REPORT OF EXAMINATION
TO APPROPRIATE PUBLIC WATERS OF THE STATE OF WASHINGTON

- Surface Water (Issued in accordance with the provisions of Chapter 117, Laws of Washington for 1917, and amendments thereto, and the rules and regulations of the Department of Ecology.)
- Ground Water (Issued in accordance with the provisions of Chapter 263, Laws of Washington for 1945, and amendments thereto, and the rules and regulations of the Department of Ecology.)

PRIORITY DATE July 2, 1976	APPLICATION NUMBER G 2-24223	PERMIT NUMBER	CERTIFICATE NUMBER
-------------------------------	---------------------------------	---------------	--------------------

NAME
RICHARD DE MEYER

ADDRESS (STREET) (CITY) (STATE) (ZIP CODE)
Route 1, Box 1599 Yelm Washington 98597

PUBLIC WATERS TO BE APPROPRIATED

SOURCE well	TRIBUTARY OF (IF SURFACE WATERS)	
MAXIMUM CUBIC FEET PER SECOND	MAXIMUM GALLONS PER MINUTE 50	MAXIMUM ACRE-FEET PER YEAR 5
QUANTITY, TYPE OF USE, PERIOD OF USE 3 acre-feet per year	irrigation of 1.5 acres	May 1 to October 1
2 acre-feet per year	group domestic supply	continuously

LOCATION OF DIVERSION/WITHDRAWAL

APPROXIMATE LOCATION OF DIVERSION-WITHDRAWAL
1200 feet East and 800 feet North from South Quarter corner, of Sec. 35.

LOCATED WITHIN (SMALLEST LEGAL SUBDIVISION) SW $\frac{1}{4}$ SE $\frac{1}{4}$	SECTION 35	TOWNSHIP N. 16	RANGE, 1E. OR W.1 W.M. 2 E	W.R.I.A. 11	COUNTY Thurston
--	---------------	-------------------	-------------------------------	----------------	--------------------

RECORDED PLATTED PROPERTY

LOT	BLOCK	OF (GIVE NAME OF PLAT OR ADDITION)
-----	-------	------------------------------------

LEGAL DESCRIPTION OF PROPERTY ON WHICH WATER IS TO BE USED

That portion of the SW $\frac{1}{4}$ SE $\frac{1}{4}$ of Sec. 35, T. 16 N., R. 2 E.W.M. lying north of Fennell Road. AND that portion to the SW $\frac{1}{4}$ SE $\frac{1}{4}$ described as follows: commencing at the SE corner, Sec. 35; thence East on the south line of said Sec. 510 feet; thence North 596 feet; thence West 255 feet; thence South 166 feet; thence West to the North-South center line of Sec. 35; thence South 430 feet to the point of beginning.

DESCRIPTION OF PROPOSED WORKS

Well - 6" x 55'

1/3 horsepower with 1" mainline to houses 3/4" line to lawn and gardens

DEVELOPMENT SCHEDULE

BEGIN PROJECT BY THIS DATE:	COMPLETE PROJECT BY THIS DATE:	WATER PUT TO FULL USE BY THIS DATE:
Started	February 7, 1979	February 7, 1980

PROVISIONS

The applicant is requesting ground water rights from a well for the purposes of group domestic supply to 3 homes and irrigation of 1.5 acres.

For a development of this nature in this area, 600 gallons per day per service will meet the water needs of each service. For 3 homes, this amounts to 2.0 acre-feet per year.

Normal irrigation requirements in this area are 2 acre-feet per year per acre. For the 1.5 acres found feasible under this application, 3 acre-feet per year will be adequate during normal irrigation season (May to October 1) each year.

Accordingly, this application may be approved for 50 gallons per minute, 2 acre-feet per year for continuous group domestic supply. An additional 3 acre-feet per year is recommended for the irrigation of 1.5 acres (May 1 to October 1) annually.


The installation of an access port as described in attached Ground Water Bulletin No. 1 shall be required prior to issuance of final certificate of water right. The applicant may for his own convenience, wish to install an airline and gage in addition to the access port.

Use of the waters to be appropriated under this application will be for a public water supply. State Board of Health rules require every owner of a public water supply to obtain written approval from the Water Supply and Waste Section, Department of Social and Health Services, Mail Stop 4-1, Building 4, Olympia, Washington, 98504, prior to any new construction or alterations of a public water supply.

Applicant is advised that notice of proof of appropriation of water (under which final certificate of water right issues) should not be filed until the permanent diversion facilities have been installed together with a mainline system capable of delivering the recommended quantity of water to an existing or proposed distribution system within the area to be served.

It is noted that well site and/or water transmission facilities are not wholly located upon the land owned by the applicant. Applicant is, accordingly, advised that the issuance of permit by this Department for appropriation of the waters in question does not convey a right of access to, or other right to use, land which the applicant does not legally possess. Obtainment of such right is a private matter between applicant and owner of that land.

Signed at Olympia, Washington,
this 7th day of July, 1977.


Jon Pace
Department of Ecology