STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

REPORT OF EXAMINATION
TO APPROPRIATE PUBLIC WATERS OF THE STATE OF WASHINGTON

☐ SURFACE WATER ☒ GROUND WATER

APPLICATION NO.	PRIORITY DATE OF APPLICATION
G2-21297	July 25, 1973

NAME
HUGH H. HANSON

ADDRESS (STREET)	(CITY)	(STATE)	(ZIP CODE)
Rt 1 Box 140	Rainier	Washington	98576

PUBLIC WATERS TO BE APPROPRIATED

SOURCE
well

TRIBUTARY OF (IF SURFACE WATERS)

MAXIMUM CUBIC FEET PER SECOND	MAXIMUM GALLONS PER MINUTE	MAXIMUM ACRE-FEET PER YEAR
	80	20

QUANTITY, TYPE OF USE, PERIOD OF USE		
1 acre-foot per year	domestic supply	continuously
19 acre-feet per year	irrigation of 10 acres	May 1 to October 1 each year

LOCATION OF DIVERSION/WITHDRAWAL

APPROXIMATE LOCATION OF DIVERSION/WITHDRAWL
500 feet west and 450 feet south from the center of Sec. 8

LOCATED WITHIN (SMALLEST LEGAL SUBDIVISION)	SECTION	TOWNSHIP N.	RANGE, (E. OR W.) W.M.	W.R.I.A.	COUNTY
E½NE¼SW¼	8	16	1 E	13	Thurston

RECORDED PLATTED PROPERTY

LOT	BLOCK	OF (GIVE NAME OF PLAT OR ADDITION)

LEGAL DESCRIPTION OF PROPERTY WATER TO BE USED ON

E½NE¼SW¼, Sec. 8, T. 16 N., R. 1 E.W.M., LESS road.

(SEE REVERSE SIDE)

DESCRIPTION OF PROPOSED WORKS

well - ~~8"~~ 10" x 150'

DEVELOPMENT SCHEDULE

BEGINNING DATE	COMPLETION DATE	DATE COMPLETE APPLICATION OF WATER TO BE MADE
July 1, 1975	July 1, 1976	July 1, 1977

PROVISIONS AND RECOMMENDATIONS

"The installation of an access port as described in attached Ground Water Bulletin No. 1 shall be required prior to issuance of final certificate of water right. The applicant may, for his own convenience, wish to install an airline and gage in addition to the access port."

The requested quantity of 80 gallons per minute is within standards allocated by this department.

There are no ground water rights of record with this office within 1/4 mile of this well site.

The annual requirement for domestic supply is based on a maximum need of 1 acre-foot for 1 home in a rural area.

The annual requirement for irrigation for this area is based on 22.8" per acre (which includes 30% application loss) or 19 acre-feet per year for 10 acres.

Additionally, the permit when issued shall carry the following provision: "Nothing in this permit shall be construed as excusing the permittee from compliance with any applicable federal, state, or local statutes, ordinances, or regulations including those administered by local agencies under the Shoreline Management Act of 1971."

Signed at Olympia, Washington,
this 25 day of June, 1974.

Dean Wood

DEAN WOOD, Resources Management
Department of Ecology

Report of Examination on Ground Water

Received date 7-25-73 Date of exam. Appli. No. G 2-21297

Name Hugh H. Hanson Address Rt. 1 Box 140 Rainier, WA 98576

Type of works Well Dimensions 8" x 150 '

Progress of works

Quantity applied for 80 Gallons per Minute g.p.m. acre-feet per year

Legal sub ~~E½NE¼SE¼~~ SW¼ Sec. 8 Twp. 16 Rge. 1 E County Thurston

Use Domestic supply and irrigation

Irrigation-acreage: Present 0 Planned 10 acres Feasible 10

Municipal: Population as of

Industrial

Time pump will be operated Continuously each year for domestic use and ~~during irrigation season~~ May 1 to Oct 1 for irrigation

Other water rights appurtenant to this land

Proximity to existing works, springs, wells, or streams

Area Sub-area Zone

RECOMMENDATIONS

Approved for 80 g.p.m. 20 acre-feet per year, subject to existing water rights. (1 acre-foot 325,850 gallons.)

$9.00 Access Port

The requested quantity of 80 GPM is within standards allocated by this Dept

There are no GW rights of record with this office within ¼ mile of this well site

The annual requirement for dom supply is based on a max need of 1 AF for 1 home in a rural area

The annual requirement for irr for

this area is based on 22.8" per acre (which includes 30% application loss) or 19 AF/yr for 10 acres

SMA

DK