STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

REPORT OF EXAMINATION
TO APPROPRIATE PUBLIC WATERS OF THE STATE OF WASHINGTON

☐ Surface Water (Issued in accordance with the provisions of Chapter 117, Laws of Washington for 1917, and amendments thereto, and the rules and regulations of the Department of Ecology.)

☒ Ground Water (Issued in accordance with the provisions of Chapter 263, Laws of Washington for 1945, and amendments thereto, and the rules and regulations of the Department of Ecology.)

PRIORITY DATE	APPLICATION NUMBER	PERMIT NUMBER	CERTIFICATE NUMBER
September 27, 1977	G 2-24677		

NAME
SHIRLEY HERMANN

ADDRESS (STREET)	(CITY)	(STATE)	(ZIP CODE)
Rt. 8 Box 441-F	Olympia	Washington	98502

PUBLIC WATERS TO BE APPROPRIATED

SOURCE
wells

TRIBUTARY OF (IF SURFACE WATERS)

MAXIMUM CUBIC FEET PER SECOND	MAXIMUM GALLONS PER MINUTE	MAXIMUM ACRE-FEET PER YEAR
	7200	non-consumptive

QUANTITY, TYPE OF USE, PERIOD OF USE		
Non-consumptive	fish propagation	continuously

LOCATION OF DIVERSION/WITHDRAWAL

APPROXIMATE LOCATION OF DIVERSION—WITHDRAWAL
1350 feet south and 1200 feet east from the center of Section 25.

LOCATED WITHIN (SMALLEST LEGAL SUBDIVISION)	SECTION	TOWNSHIP N.	RANGE, (E. OR W.) W.M.	W.R.I.A.	COUNTY
E½	25	16	4 W	23	Thurston

RECORDED PLATTED PROPERTY

LOT	BLOCK	OF (GIVE NAME OF PLAT OR ADDITION)

LEGAL DESCRIPTION OF PROPERTY ON WHICH WATER IS TO BE USED

That part of the W½ of Section 30 and the W½NW¼ of Section 31, T. 16 N., R. 3 W.W.M. and of the E½ of Section 25, T. 16 N., R. 4 W.W.M. bounded by the north and west by right-of-way of Northern Pacific Railroad Company and on the south by Black River; and that part of the SW¼SW¼ of said Section 30, Lying southerly of said river, in Thurston County, Washington.

DESCRIPTION OF PROPOSED WORKS

Plans are to build 16 concrete circular ponds, 50' in diameter with a water depth of 4'. These ponds will discharge into a 50'x150' earth pond. Water will be piped to a 4 acre (surface area) reservoir.

DEVELOPMENT SCHEDULE

BEGIN PROJECT BY THIS DATE:	COMPLETE PROJECT BY THIS DATE:	WATER PUT TO FULL USE BY THIS DATE:
December 1, 1978	December 1, 1981	December 1, 1982

PROVISIONS

The applicant will engage in a fish farming operation raising salmon to plate size as a commercial enterprise. The facility will rely on ground water for its operation, in rearing 500,000 pounds of fish per year.

An attempt will be made to drill production wells capable of pumping 7200 gpm. The water right certificate will be issued for the amount of water developed.

Permit, when issued, will be subject to the following provision: "No more than 7200 gpm shall be withdrawn from the ground water system."

The installation of an access port as described in attached Ground Water Bulletin No. 1 shall be required prior to issuance of final certificate of water right. The applicant may for his own convenience, wish to install an airline and gage in addition to the access port.

"All water wells constructed within the state shall meet the minimum standards for construction and maintenance as provided under Chapter 18.104 RCW (Washington Water Well Construction Act of 1971) and Chapter 173-160 WAC (Minimum Standards for Construction and Maintenance of Water Wells)."

Signed at Olympia, Washington,
this 5th day of December, 1977.

Jon Pace

Jon Pace
Department of Ecology