

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

PERMIT

TO APPROPRIATE PUBLIC WATERS OF THE STATE OF WASHINGTON

Surface Water (issued in accordance with the provisions of Chapter 117, Laws of Washington for 1917, and amendments thereto, and the rules and regulations of the Department of Ecology.)

Ground Water (issued in accordance with the provisions of Chapter 263, Laws of Washington for 1946, and amendments thereto, and the rules and regulations of the Department of Ecology.)

PRIORITY DATE January 22, 1991	APPLICATION NUMBER G2-28004	PERMIT NUMBER G2-28004 P	CERTIFICATE NUMBER
-----------------------------------	--------------------------------	-----------------------------	--------------------

NAME
Trillium Corporation c/o Wilson and Associates

ADDRESS (STREET) 805 Dupont Street #7	(CITY) Bellingham	(STATE) Washington	(ZIP CODE) 98225
--	----------------------	-----------------------	---------------------

The applicant is, pursuant to the Report of Examination which has been accepted by the applicant, hereby granted a permit to appropriate the following described public waters of the State of Washington, subject to existing rights and to the limitations and provisions set out herein.

PUBLIC WATERS TO BE APPROPRIATED

SOURCE
A well

TRIBUTARY OF (IF SURFACE WATER)

MAXIMUM CUBIC FEET PER SECOND	MAXIMUM GALLONS PER MINUTE 10	MAXIMUM ACRE-FEET PER YEAR 7.0
-------------------------------	----------------------------------	-----------------------------------

QUANTITY, TYPE OF USE, PERIOD OF USE
7.0 Acre-feet per year Group domestic supply (14 homes) Year-round, as needed

LOCATION OF DIVERSION/WITHDRAWAL

APPROXIMATE LOCATION OF DIVERSION-WITHDRAWAL
200 feet north and 1100 feet east of the west quarter corner of Section 19.

LOCATED WITHIN (SMALLEST LEGAL SUBDIVISION) SW¼NW¼	SECTION 19	TOWNSHIP N. 29	RANGE, (E. OR W.) W.M. 1E	W.R.L.A. 17	COUNTY Jefferson
---	---------------	-------------------	------------------------------	----------------	---------------------

RECORDED PLATTED PROPERTY

LOT	BLOCK	OF (GIVE NAME OF PLAT OR ADDITION)
-----	-------	------------------------------------

LEGAL DESCRIPTION OF PROPERTY ON WHICH WATER IS TO BE USED

Lots 1 through 14 of Skywater Large Lot Subdivision, Jefferson County, Washington.

DESCRIPTION OF PROPOSED WORKS

A 6" x 231' well with a 1.5 horsepower pump, 29,000 gallon reservoir, and 6" pvc mainline.

DEVELOPMENT SCHEDULE

BEGIN PROJECT BY THIS DATE Started	COMPLETE PROJECT BY THIS DATE Completed	WATER PUT TO FULL USE BY THIS DATE May 1, 1993
---------------------------------------	--	---

PROVISIONS

Installation and maintenance of an access port as described in WAC 173-160-355 is required. An air line and gauge may be installed in addition to the access port. Water levels shall be measured and recorded using a consistent methodology, in accordance with accepted industry standards. Such measurements shall be made at least monthly. The length of the pumping period or recovery period prior to each measurement shall be constant, and shall be included in the record.

At such time that the Department of Ecology determines the regulation and management of the subject waters is necessary and in the public interest, an approved measuring device shall be installed and maintained in accordance with RCW 90.03.360 and WAC 508-64-020 through -040.

This permit may be subject to implementation of the minimum requirements established in the Interim Guidelines for Public Water Systems Regarding Water Use Reporting, Demand Forecasting Methodology and Conservation Programs, July 1990.

Under RCW 90.03.005 and 90.54.020(6), conservation and improved water use efficiency must be emphasized in the management of the State's water resources, and must be considered as a potential new source of water. Accordingly, as part of the terms of this permit, the applicant may need to prepare and implement a water conservation plan approved by Department of Health. The standards for such a plan may be obtained from either the Department of Health or the Department of Ecology.

The Water Resources Act of 1971 specifies certain criteria regarding utilization and management of the waters of the state in the best public interest. Use of water may be subject to regulation at certain times, based on the necessity to maintain water quantities sufficient for preservation of the natural environment.

The applicant is advised that notice of proof of appropriation of water (under which the final certificate of water right is issued) should not be filed until the permanent diversion facilities have been installed, and the system is currently in use. This includes installation of a mainline system capable of delivering the recommended quantity of water to an existing or proposed distribution system within the area to be served.

This permit shall be subject to cancellation should the permittee fail to comply with the above development schedule and/or fail to give notice to the Department of Ecology on forms provided by that Department documenting such compliance.

Given under my hand and the seal of this office at Olympia, Washington,

this 3rd day of August, 1992.

Chuck Clarke, Director

Department of Ecology

ENGINEERING DATA

OK JB

by Gale Blomquist