

REPORT OF EXAMINATION

Date of application 7-25-62 Date of examination 8-15-62 Application No. 17413
Name L. P. & Dolores Snyder Address Rt. 3, Box 45, Olympia, Washington
Quantity applied for 0.01 c.f.s. Use domestic supply and lawn irrigation
Source of appropriation Perclval Creek Tributary of Capitol Lake
Legal sub. Gov't. Lot 3 Sec. 34 Twp. 18 N. Rge. 2 W. County Thurston
Measured or estimated quantity 4.5 c.f.s. Probable low flow 3 c.f.s. (?)
Quantity previously appropriated: W.T. 0.79 c.f.s.* CWT. _____ E.T. _____
Other use made of water irrigation
Diversion works contemplated or observed 1 hp cent. pump, 2" intake, pressure tank at creek,
Other equipment _____
Irrigable acreage: Planned _____ Present about 1/2 acre Feasible 1 acre
Other water rights appurtenant to this land domestic well to serve trailer court
Progress of project complete and in use
Protests _____
Quantity recommended (total) 0.01 c.f.s. Irrig. domestic Dom. _____
Power Municipal Other uses _____
Department of Fisheries and Game report See below

Special remarks and provisions:

In accordance with the recommendations of the Departments of Fisheries and Game, permit shall be subject to the following provisions:


- (1) Diversion intake shall be tightly screened at all times with wire having a mesh opening not greater than 0.125 (1/8) inch.
- (2) No dam shall be constructed in connection with this diversion.

*Previously appropriated are 0.60 c.f.s. from Perclval Creek and 0.19 c.f.s. from Troesper Lake draining to Perclval Creek, all consumptive users.

In accordance with section 90.03.290 R.C.W., I find that there is water available for appropriation from the source in question and that the diversion proposed in the application will not impair existing

rights or be detrimental to the public welfare. Therefore, permit should issue as recommended above,
subject to existing rights and indicated provisions.

Signed this 11th day of September, 1962
Division of Water Resources


John B. Noble, Geologist