

Proposal # 11-026, as modified by Fire Code TAG on May 16, 2011

Original Proponent: Lance Talley, WSFM

In the IFC amend the charging paragraph (907.2.6) as follows:

'.....in accordance with Section 907.2.6.1 through ~~907.2.6.3.3~~ 907.2.6.4'

In the IBC amend the charging paragraph (907.2.6) as follows:

'...in accordance with Sections 907.2.6.1, 907.2.6.2, ~~and~~ 907.2.6.3 and 907.2.6.4'

In the IFC and the IBC amend Section 907.2.6 as follows:

907.2.6.4 Group I-4 Child care facilities. An automatic smoke detection system that activates the occupant notification system in accordance with sections 907.6 thru 907.6.2.3.2 shall be provided and installed in accordance with NFPA 72.