



STATE OF WASHINGTON

**STATE BUILDING CODE COUNCIL**

1500 Jefferson Street • P.O. Box 41449 • Olympia, Washington 98504-1449  
 (360) 407-9280 • fax (360) 586-5366 • e-mail sbcc@ga.wa.gov • www.sbcc.wa.gov

November 2012 Motions for Rule Making Actions

Main Motion: Adopt 2012 Energy Code as proposed in WAC 51-11R and 51-11C; repeal WAC 51-11

Amendment to the main motion:

Amend Table C402.2 to correct thermal block R-value for metal buildings:

**Table C402.2**  
**Opaque Thermal Envelope Requirements<sup>a, f</sup>**

CLIMATE ZONE	5 AND MARINE 4		6	
	All Other	Group R	All Other	Group R
<b>Roofs</b>				
Metal buildings (with <del>R-5</del> <u>R-3.5</u> thermal blocks) <sup>a,b</sup>	<b>R-19 + R-11 LS</b>	<b>R-19 + R-11 LS</b>	<b>R-25 + R-11 LS</b>	<b>R-25 + R-11 LS</b>

**Rationale:** Error in table noted by Metal Buildings Manufacturers Association, value noted in ASHRAE 90.1 table is R-3.5.