



Washington State Building Code Council

Improving the built environment by promoting health, safety and welfare

1500 Jefferson Street SE • P.O. Box 41449 • Olympia, Washington 98504
(360) 407-9280 • fax (360) 586-5366 • e-mail sbcc@ga.wa.gov • www.ga.wa.gov/sbcc

STATE BUILDING CODE INTERPRETATION NO. 14-01

- CODE:** 2012 Washington State Energy Code, Commercial
- SECTION:** C101.4.3 Additions, alterations, renovation or repair
C402.4.1.2.3 Air leakage, Building test
- QUESTION:** If an alteration, renovation or repair includes envelope assemblies, is this area required to be tested for air leakage?
- ANSWER:** **No, air leakage testing is not intended for alterations or repairs as long as the alteration does not include a change in use or change in space conditioning.**
- SUPERSEDES:** None
- REQUESTED BY:** Pierce County