

**903.2.3 Group E.** An automatic sprinkler system shall be provided for Group E Occupancies.

**Exceptions:**

1. A portable school classroom structure with an occupant load of 150 or less calculated in accordance with Table 1004.1.2; provided that a) the aggregate area of any cluster of portable school classrooms does not exceed 5,000 square feet; b) ~~and all exits required by code shall be direct to the exterior;~~ and c) clusters of portable school classrooms shall be separated as required by the building code; or-

2. Group E occupancies with an occupant load of 50 or less, calculated in accordance with Table 1004.1.2.