



STATE OF WASHINGTON

STATE BUILDING CODE COUNCIL

906 Columbia Street SW • P.O. Box 48300 • Olympia, Washington 98504-2525 • (360) 725-2967

STATE BUILDING CODE INTERPRETATION NO. 00-05

- CODE:** 1997 Uniform Building Code (UBC),
State Regulations for Barrier-Free Facilities
- SECTION:** Section 1106.11.10 Shower Stalls
Section 1106.27 Dwelling Units
- QUESTION:** The American National Standard ICC/ANSI A117.1-1998 specifies a 36 inches by 36 inches transfer shower stall for Type A dwelling units. For Type B dwelling units, however, it specifies 36 inches by 36 inches as *minimum* dimensions. This appears to differ from the state code requirement which gives only a specific size for transfer shower stalls in Section 1106.11.10. Does the 36 inches by 36 inches transfer shower stall requirement of Section 1106.11.10 apply to Type B dwelling units?
- ANSWER:** Yes.
- SUPERSEDES:** None
- REQUESTED BY:** Spokane County