

**WAC 51-54A-0105 Permits.**

**SECTION 105 SCOPE AND GENERAL REQUIREMENTS**

**105.1.1 Permits required.** Any property owner or authorized agent who intends to conduct an operation or business, or install or modify systems and equipment, which is regulated by this code, or to cause any such work to be done shall first make application to the fire code official and obtain the required permit.

**105.6.4 Carbon dioxide systems.** An operational permit is required for carbon dioxide systems having more than 100 pounds of carbon dioxide.

~~((105.6.4.9))~~ **105.6.49 Marijuana extraction systems.** An operational permit is required to use a marijuana/cannabis extraction system regulated under WAC 314-55-104.

**105.7.19 Marijuana extraction systems.** A construction permit is required to install a marijuana/cannabis extraction system regulated under WAC ~~((244-55-104 [WAC 314-55-104]))~~ 314-55-104.

**105.7.20 Underground supply piping for automatic sprinkler system.** A construction permit is required for the installation of the portion of the underground water supply piping, public or private, supplying a water-based fire protection system. The permit shall apply to all underground piping and appurtenances downstream of the first control valve on the lateral piping or service line from the distribution main to one foot above finished floor of the facility with the fire protection system. Maintenance performed in accordance with this code is not considered to be a modification and does not require a permit.

- EXCEPTIONS:
1. When the underground piping is installed by the aboveground piping contractor.
  2. Underground piping serves a fire protection system installed in accordance with NFPA 13D.